# Online Comment

| | |
|---|---|
| **Application** | H02-0330-18 |
| **Location** | 49 PETERBOROUGH ROAD CROWLAND PETERBOROUGH PE6 0BB |
| **Proposal** | Residential development - proposed bungalow |

---

| | |
|---|---|
| **Name** | Sue Armour |
| **Address** | Environmental Protection Officer South Holland District Council |
| **Date Submitted** | 30-04-18 |
| **For/Against** | Comments |

Due to a number of filled pits/ponds in the area I would ask for the following condition:

a)Investigate the site for landfill gas to the satisfaction of the LPA, to ascertain whether gas protection measures are required. Where measures are required the details shall be submitted to, and approved by, the LPA.
OR
b)The applicant shall install gas protection measures as a precautionary measure without first investigating the site. The details of these measures shall be submitted to, and approved by, the LPA.

c) For a) and b) all required measures shall be installed before the development is first occupied.