SOUTH HOLLAND DISTRICT COUNCIL

Town and Country Planning Act 1990

Observations of Local Planning Authority

Reference: H02/0348/93 Received:19-APR-93 Type:ELECTRICITY

Name: East Midlands Electricity plc
Sleaford Road
Boston
Lincs
PE21 8BR

Agent: East Midlands Electricity plc
Sleaford Road
Boston
Lincs
PE21 8BR

Description: Proposed 11,000 volt overhead line

Location : Parish of Crowland

South Holland District Council has considered the proposal and has NO OBJECTIONS to the development, subject to any comments set out below:

Director of Planning and Building Control Services
15-JUN-93 H02/0348/93

This decision refers only to that required for the purposes of the Town and Country Planning Act and not for Building Regulations or any other legislation. See enclosed notes relating to rights of appeal.

BRIAN SMITH Dip TP MRTPI Director of Planning & Building Control Services

Planning & Building Control Department, Council Offices, Priory Road, Spalding, Lincolnshire. PE11 2XE (Tel: 0775 761161)

APPL[illegible]ATION ASSESSMENT

Notes for Case Officer

Site Inspection

Accuracy :
Neighbours :
Boundaries :
Site Features :

Inspected by PJM
Date 4/5

Site Notice posted by
Date
Expiry No need

Individual Resident Notices required:

Addresses to be sent to –

Addresses delivered to –

Case Officer Conclusions

Open plan feel between two banks
No trees or L Bunds affected
Is a CH line to South of this proposal

RECOMMENDATION

COMMITTEE

Departure from Policy .....

Ward Member request .....

Recommend approval against material objection .....

Other circumstances viz: .....

Change to Committee recorded:

Decision confirmed as agenda:

DELEGATED/Non-Det

Case Officer Recommendation

Approve (or equiv)

Refuse (or equiv)

Signed ..... Date.....

Notes:

- [ ] Disabled
- [ ] Prev conditions
- [ ] Amended plans – Dwg no: Received:

Conditions/Reasons (cont overleaf)

DC INSTRUCTION SHEET

APPLICATION REF:

Directions

Art 7 (Outlines)

☐ RM checklist

	Sit	Des	Ext	Acc	Land
Previous					
Current					
Required					

Reg 4 Scale drawing.... Highway S/W.... Agric appraisal....

☐ Non Std

Precise details:

Direction authorised by Senior Officer..... Date.....

Revalidation after Direction

Information satisfactory Signed..... Date.....

Valid date:

Amended description

Reconsultations:

All.....
Specified:

Unsatisfactory –
Further direction:
Signed.....
Senior Off.....

Precise details:

Consultation/Publicity Required

Para 23-4 agree comments re Sch 9 of Electricity Act do we need to go to Nature Conservancy as NRA suggested?

	Publicity:		Consultations:	
Departure	.....		County	.....
Setting of LB	.....	TR 29/6	E Heritage	.....
Public Right of Way	.....		Societies	.....
Discretionary	.....			

Extra Consultations:

Transport	D/Transp A15	..... *		
	D/Transp A18	.....		
	B Rail	.....		
Environment	Env Services	.....		
	NRA	.....		
	Env Assess	..... G *		Specify:
Conservation	LB Demolish	..... G *		Standard
	Eng Heritage	.....		
	Archaeology	..... G		Specify:
	Consultant	.....		
	Other	.....		Specify:
Hazards	HSC Group	..... G *		Standard
	Specific	..... G		Specify:
Other		.....		Specify:

Note
* Longer expiry
G Group available

Case Officer

Senior Officer Confirmed ....PM... Date..... Recorded DC....

ADMIN RECORD SHEET

Initial

Submitted Fee £ NIL

Receipt No

Date first Rec'd 19 APR 1993

Registration

Reference H02/0348/93

Cross-Ref N/A

Date 20/4/93

Validation

TYPE DEL

Site area
No of dwellings
Floorspace

Earlier permission – Ref:
New/Redevelop/Use/Ext/Alt/Works

Description to be recorded

Invalid
Site plans ☐
Certificate ☐
Fee ☐
Fee (not free) ☐
Inaccurate ☐
Incomplete ☐
Unclear ☐

Fees
Correct fee £ NIL
Nil fee ☐
Discounted ☐
Previous app – ref:
Type of app
Reason:

Additional £
Refund £
Receipt No
Voucher No
Date
Date

Information

Index sheet 369 OS Plots
Grid ref 523280 311490

Ward A
Parish CROWLAND

Inside IBD NO
Inside LP area NO

Constraints:

CA Cons Area ☐
LB Listed – Grade: ☐
ARC Archaeology ☐
AM Ancient Mon ☐
SSI Special Int YES

Hazards –
Dist Bound ☐
Other: BRIDLEWAY

TR Rural ☐
BP TR proposed 67m ☐
LC Level Cross ☐
FP Footpath YES
TPO Tree Pres ☐
HAZ Site ☐
AIR Safeguard ☐
LIN Elect ☐
PIP Pipe ☐
CON Waste/contamin ☐

Linked to site Ref 1277

Linked to property Ref

Planning Records:
Earlier apps

B Reg Records:
Already submitted – Ref:
Request needed
Requested

APPLICATION REFERENCE: H02/0348/93 DATE RECEIVED: 19-APR-93

TYPE: Electricity

DESCRIPTION: Proposed 11,000 volt overhead line

LOCATION: Parish of Crowland

APPLICANT: East Midlands Electricity plc AGENT:

REASON FOR COMMITTEE CONSIDERATION

Comments from the Parish Council.

RECOMMENDATION

No objections.

SOUTH HOLLAND DISTRICT COUNCIL
REPORT TO PLANNING COMMITTEE
Date - 8 JUN 1993

COMMENTS

1 The proposal is for an overhead line between Cloot Drove and Common Drove. There will also be a new line in a northward direction located west of the River Welland. Part of this will be an overhead line and part of it will be underground. The Parish Council require this to be fully underground.

2 Whilst I can appreciate this point the short length involved is satisfactory. Raising objections will result in a public inquiry. There are technical reasons why more of the line cannot be undergrounded and these will be verbally reported.

REPRESENTATIONS

Parish Council: Support the move to underground cable adjacent 847 Common Farm, Crowland but suggest undergrounding is extended south to where the line crosses the river.

---

416. PLANNING APPLICATIONS (Continued)

(g) **Applications approved subject to Planning Obligations** (Continued)

(It was agreed that planning permission be granted for the above development subject to the access being relocated to the southern part of the application site.)

(It was also agreed that an order be made under Section 97 of the Town and Country Planning Act 1990 revoking planning permission H14/1719/88 subject to the owners and occupiers of the land and all other persons who will be affected by the order confirming in writing that they do not object to the order and will not be claiming any compensation under Section 107 of the Town and Country Planning Act 1990.)

(h) **Observations on applications by East Midlands Electricity Plc**

East Midlands Electricity Plc be advised that this authority raises no objections to the undermentioned developments, in accordance with the recommendations of the Director of Planning and Building Control Services:-

Plan No. and Applicant	Proposal
H02/0348/93 East Midlands Electricity Plc	11,000 volt overhead line in the Parish of Crowland.
H02/0349/93 East Midlands Electricity Plc	11,000 volt overhead line in the Parishes of Crowland and Newborough.

(i) **Observations on applications by Lincolnshire County Council**

The Lincolnshire County Council be advised of this authority's views in respect of the undermentioned proposals as follows:-

Plan No. and Applicant	Proposal
H02/0390/93 G M Riddington	Lagoon for storage of abattoir washings and vegetable processing liquid waste at Decoy Farm, Postland.

(The Lincolnshire County Council be advised that this authority objects to the above proposal, in accordance with the recommendation of the Director of Planning and Building Control Services, and be requested to refer the matter back to the appropriate committee for further consideration in view of concern that this authority's views were not taken into account when the application was discussed, notwithstanding the fact that the County Council had been advised of the likely objection.)

H16/0412/93 Birse Construction Ltd	Excavation of borrow pit to provide material for by-pass, and subsequent reinstatement as lake south east of A16 Spalding by-pass and east of A1073 Cowbit Road, Spalding.

(The Lincolnshire County Council be advised that this authority objects to the above development in accordance with the recommendation of the Director of Planning and Building Control Services and in particular is concerned at the proposed location of the development which, in any event, it is understood, is situated within the area the subject of the proposed A1073 improvement scheme.)

BRI SMITH Dip TP MRTPI
Dire of Planning & Building Control Services
Planning & Building Control Department,
Council Offices,
Priory Road, Spalding,
Lincolnshire. PE11 2XE

Telephone: (0775) 761161
Fax: (0775) 710772

SOUTH HOLLAND DISTRICT COUNCIL

H02/0348/93
ELECTRICITY

Applicant: East Midlands Electricity plc Agent: East Midlands Electricity
Tel: 0205 365181 0205 365181

Description: Proposed 11,000 volt overhead line

Location: Parish of Crowland

Valid date:	19-APR-93	Terminal date:	14-JUN-93
Target dates:		Target Committee:	08-JUN-93
To case officer	26-APR-93	Report deadline:	25-MAY-93
Inspected by	03-MAY-93		
Extra contacts	10-MAY-93	Case Officer:	
Report if not clear by	24-MAY-93	P J UDY	

DEVELOPMENT/CONSTRAINTS

Size:
Category:
Listed building: SSSI Other Constraints: FP
Conservation Area:

CONSULTATIONS CARRIED OUT

	Sent	Expiry
Clerk to Crowland PC 0733 210653	11-MAY-93	25-MAY-93
Clerk to Crowland PC 0733 210653	26-APR-93	10-MAY-93
Cllr B Alcock 0733 210560	26-APR-93	03-MAY-93
Cllr N H Pepper Peterborough 21	26-APR-93	03-MAY-93

Lis - No objection - JAS 4/5/93

SITE RECORD

P.T.O.

Grid ref: 523280 311490
OS Sheet: 369 Parcel:

BR SMITH Dip TP MRTPI
Director of Planning & Building Control Services
Planning & Building Control Department,
Council Offices,
Priory Road, Spalding,
Lincolnshire. PE11 2XE
Telephone: (0775) 761161
Fax: (0775) 710772

Cam

SOUTH HOLLAND DISTRICT COUNCIL

H02/0348/93

ELECTRICITY

Applicant: East Midlands Electricity plc Agent: East Midlands Electricity
Tel: 0205 365181 0205 365181

Description: Proposed 11,000 volt overhead line

Location: Parish of Crowland

Valid date: 19-APR-93
Target dates:
To case officer 26-APR-93
Inspected by 03-MAY-93
Extra contacts 10-MAY-93
Report if not clear by 24-MAY-93

Terminal date: 14-JUN-93
Target Committee: 08-JUN-93
Report deadline: 25-MAY-93

Case Officer:
P J UDY

DEVELOPMENT/CONSTRAINTS

Size:
Category:
Listed building: SSSI
Conservation Area:

Other Constraints: FP

CONSULTATIONS CARRIED OUT

		Sent	Expiry
c c - No objection 26/4/93			
Clerk to Crowland PC	0733 210653	26-APR-93	10-MAY-93
Cllr B Alcock	0733 210560	26-APR-93	03-MAY-93
Cllr N H Pepper	Peterborough 21	26-APR-93	03-MAY-93

SITE RECORD

P.T.O.

Grid ref: 523280 311490
OS Sheet: 369 Parcel:

H 02/0349/93
H02/0348/93

...ENGINEERING DEPT.
...1993

SCHEMES OF WORK: CROWLAND/DEEPING FEEDER AND NEWBOROUGH FEEDER

OVERALL OBJECTIVE:

To increase the security of supply to all customers between Crowland and Peterborough, including Peterborough Road, Crowland; Wrights Drove; Speechley Drove; Nene Terrace; Powder Blue; Newborough village; Milking Nook and Willow Drove.
This area has suffered 24 supply interruptions in the last 2 years. The Customers in this area have written numerous complaints. East Midlands Electricity have held a number of meetings with residents and Newborough Parish Council. This has convinced E.M.E. that to " do nothing" is not an option.

PROPOSALS:

The most effective way of increasing the reliability to this area is to build a new 11,000 volt feeder direct to Newborough Village and split off the Village from Peterborough Road, Nene Terrace, Powder Blue etc.

To do this would involve a new feeder from the primary sub-station to the north of Crowland passing around the village of Crowland along Corporation Bank and along Willow Drove. There is already an 11,000 volt line on the first section of this route which then turns to the north west to feed the Deepings area. Rather than build a new line parallel to the existing one it is proposed to utilise the existing line to connect to the new feeder to Newborough and build a new line due west from the primary sub-station to pick up the existing line towards the Deepings.

The Company standard across open farm land at 11,000 volts is overhead lines consisting of wood poles at an average spacing of 90 metres with 3 separate aluminium conductors, this is preferred to underground cable because on average U/G cable is 50% more expensive.

In the particular case of Corporation Bank the ground conditions are ideal to lay cable as economically as possible, this coupled with the fact that the line would be parallel to the river and could suffer from a high level of bird strikes makes the choice between overhead and underground borderline. We have chosen U/G as this has the added advantage of being better visually.
The same argument applies to Willow Drove, Newborough, as the ground conditions are similar to Corporation Bank in so much as there is a grass verge with no other services in it. We have again decided to lay U/G cable on this route.

The sections of overhead line at Drove cottages, Crease Drove and Thorney Machinery have to be left for the present time, but if development takes place providing a viable underground cable route they could be removed.

Undergrounding of overhead lines is technically advantageous if large sections can be completed. But in situations where there are numerous small pole mounted transformers, there is no low cost ground mounted alternative and to leave the transformers on poles introduces a lightening risk to the cable network.

The termination of the new section of overhead line on the eastern end of Corporation Bank has to be on a 2 pole structure, which we could not get permission to site on the farm land, but had to come through onto Corporation Bank.

S.H.D.C. PLANNING DEPT.
RECEIVED
- 2 JUN 1993

Attention of
DPO NRM
cDPO SS
JC ACP
Action by .....
Discuss with .....
Copy to .....

File Nos.

Acknowledge YES/NO
By
Date

BRIAN SMITH Dip TP MRTPI
Director of Planning & Building Control Services
Planning & Building Control Department,
Council Offices,
Priory Road, Spalding,
Lincolnshire. PE11 2XE

Telephone: (0775) 761161
Fax: (0775) 710772

SOUTH HOLLAND DISTRICT COUNCIL

S.H.D.C. PLANNING DEPT
RECEIVED
21 MAY 1993

Attention of	File Nos.
DPO NRM DOPO BS JC ACP Action by ..... Discuss with ..... Copy to	Acknowledge YES/NO by date

Application no: H02/0348/93

Applicant: East Midlands Electricity plc
Sleaford Road
Boston
Lincs
PE21 8BR

Agent: East Midlands Electricity p
Sleaford Road
Boston
Lincs
PE21 8BR

Description: Proposed 11,000 volt overhead line

Location: Parish of Crowland

Type: ELECTRICITY

Date received: 19-APR-93

11-MAY-93

Dear Sir/Madam

CONSULTATION WITH PARISH COUNCIL

I have received an application for the above proposal and enclose a copy for your information. Any observations which the Parish Council wish to make should be set out below and returned to me by 25-MAY-93. If no observations have been received by that date, it will be assumed that the Parish Council have no comments to make. The officer dealing with this application is P J UDY

Yours faithfully
B SMITH
Director of Planning and Building Control Services

Clerk to Crowland PC
10 Beccelm Drive
Crowland
Peterborough
PE6 0AG

FOR PARISH COUNCIL USE ONLY

Comments:

We support the move to underground the cable adjacent to 84 Common Farm Crowland but suggest the undergrounding is extended south to where the line crosses the river — this would ~~help~~ reduce the impact on the environment.

Signed: Paul E Smith
20/5/93

BRIAN SMITH Dip TP MRTPI
Director of Planning & Building Control Services
Planning & Building Control Department
Council Offices,
Priory Road, Spalding,
Lincolnshire. PE11 2XE

Telephone: (0775) 761161
Fax: (0775) 710772

S.H.D.C. PLANNING DEPT.
RECEIVED
10 MAY 1993
Acknowledge YES/NO
SUPERSEDED

SOUTH HOLLAND DISTRICT COUNCIL

Application no: H02/0348/93

Applicant: East Midlands Electricity plc
Sleaford Road
Boston
Lincs
PE21 8BR

Agent: East Midlands Electricity p
Sleaford Road
Boston
Lincs
PE21 8BR

Description: Proposed 11,000 volt overhead line

Location: Parish of Crowland

Type: ELECTRICITY

Date received: 19-APR-93

26-APR-93

Dear Sir/Madam

CONSULTATION WITH PARISH COUNCIL

I have received an application for the above proposal and enclose a copy for your information. Any observations which the Parish Council wish to make should be set out below and returned to me by 10-MAY-93. If no observations have been received by that date, it will be assumed that the Parish Council have no comments to make. The officer dealing with this application is P J UDY

Yours faithfully
B SMITH
Director of Planning and Building Control Services


Clerk to Crowland PC
10 Beccelm Drive
Crowland
Peterborough
PE6 0AG

FOR PARISH COUNCIL USE ONLY

Comments:

We are unhappy about the proliferation of usually unsightly wires around Crowland. They will also be an additional hazard to birds many of them (especially Swans) get killed every year. We would prefer underground cables

~~Signed:~~ Paul E Smith 6/5/93



NRA

National Rivers Authority
Anglian Region

14th May 1993

B Smith Esq
District Planning Officer
South Holland District Council
Council Offices
Priory Road
SPALDING
Lincolnshire
PE11 2XE

Our Ref: 93/1/SH/0122
Contact: GILL THORNALLEY

Dear Sir,

Planning Application No. H02/0348/93

PROPOSAL: PROPOSED 11,000 VOLT OVERHEAD LINE
LOCATION: CROWLAND
APPLICANT: EAST MIDLANDS ELECTRICITY PLC

I refer to your consultation received on 28th April 1993.

This Authority has no objection to the proposed development, as submitted.

The following planning informatives should be attached to any planning permission granted:-

Planning Informatives

Under the terms of the Water Resources Act 1991 and the Land Drainage Byelaws, the prior written consent of the NRA is required for any proposed works or structures in, under, over or within 9m byelaw distance of the main river Welland.

The River Welland is a major flayway for water foul, especially swan and EME plc should consider the placing of cables in thrustbore below the river, to prevent obstruction and hazard in the flyway. Where this is not possible overhead cables should cross near bridges or areas where waterfowl give a wide berth. In any event bird flight indicators should be placed on overhead cables.

Warning signs should also be erected adjacent to overhead cable crossings to warn water users of overhead hazards.

Power cables should not run within 30m of open water to avoid hazard to

contd ...

GRAINGER DAVIES, B.Sc.,
C.Eng., F.I.C.E., F.I.W.E.M.
Regional General Manager

Northern Area
Aqua House
Harvey Street
Lincoln
LN1 1TF
Tel: (0522) 513100
Telefax: (0522) 512927

NRA

fishermen as recommended by the National Federation of Anglers.

Yours faithfully

R.Morgan
Planning Engineer

PLANNING AMENDMENT

For office use only

Application No. 1409/348/93

Date registered 05 MAY [illegible] PJ

Case Officer

1. Please complete in block letters **NAME AND ADDRESS OF APPLICANT** Tel. No.	**NAME AND ADDRESS OF AGENT** (if form completed by agent) Tel. No. (Contact)

Please complete in block letters
FULL POSTAL ADDRESS OF THE APPLICATION SITE

Please complete **EARLIER APPLICATION No.** This application **cannot be considered** unless the relevant reference is stated	
Building Regulation reference relating to same development.	

2. Please tick **one** box only

A. Amendment is proposed where permission already granted ☐
If yes, submit two forms and two plans

or

B. Amendment is to a proposal currently being considered ☐
If yes, submit four forms and four plans.
State whether amendment has been requested by the Council ☐

Has a similar amendment been submitted under Building Regulations? Yes / No

Please complete

I attach the necessary plans and request that the changes described below be accepted as an amendment. I understand that the Council may require a fresh application, together with fee if appropriate.

Signed ..... Date .....

3. Please complete in block letters **FULL DESCRIPTION OF DEVELOPMENT IN ORIGINAL APPLICATION**	
As NOW PROPOSED, if different	
State details of amendments proposed (Give a full detailed list of the changes, and also mark these clearly on the accompanying plans)	
State drawing no's of the current submission	
State Officer dealing with the application, if known.	
Describe any part of the original development which is excluded by virtue of the amendment, and state any alteration to plot numbers	

SCHEDULE 9

Section 38.

PRESERVATION OF AMENITY AND FISHERIES.

Preservation of amenity: England and Wales

1.—(1) In formulating any relevant proposals, a licence holder or a person authorised by exemption to generate or supply electricity—

(a) shall have regard to the desirability of preserving natural beauty, of conserving flora, fauna and geological or physiographical features of special interest and of protecting sites, buildings and objects of architectural, historic or archaeological interest; and

(b) shall do what he reasonably can to mitigate any effect which the proposals would have on the natural beauty of the countryside or on any such flora, fauna, features, sites, buildings or objects.

(2) In considering any relevant proposals for which his consent is required under section 36 or 37 of this Act, the Secretary of State shall have regard to—

(a) the desirability of the matters mentioned in paragraph (a) of sub-paragraph (1) above; and

(b) the extent to which the person by whom the proposals were formulated has complied with his duty under paragraph (b) of that sub-paragraph.

(3) In this paragraph—

"building" includes structure;

"relevant proposals" means any proposals—

(a) for the construction or extension of a generating station of a capacity not less than 10 megawatts, or for the operation of such a station in a different manner;

(b) for the installation (whether above or below ground) of an electric line; or

(c) for the execution of any other works for or in connection with the transmission or supply of electricity.

(4) The Secretary of State may by order provide that sub-paragraph (3) above shall have effect as if for the capacity mentioned in paragraph (a) there were substituted such other capacity as may be specified in the order.

(5) This paragraph and paragraph 2 below extend to England and Wales only.

2.—(1) A licence holder shall within twelve months from the grant of his licence prepare, and from time to time modify, a statement setting out the manner in which he proposes to perform his duty under paragraph 1(1) above, including in particular the consultation procedures which he intends to follow.

(2) Before preparing or modifying a statement under this paragraph, a licence holder shall consult with the Countryside Commission, the Nature Conservancy Council and—

(a) where the activities which he is authorised by his licence to carry on include activities in England, the Historic Buildings and Monuments Commission for England; and

(b) where those activities include activities in Wales, the Historic Buildings Council for Wales.

(3) As soon as practicable after preparing or modifying a statement under this paragraph, the licence holder shall publish the statement as so prepared or so modified in such manner as he considers appropriate.

H02/0348/93

APR 1993

Form B (Type III)

Notes: This Form is for use in connection with an application for the Secretary of State for Energy's consent under **section 37** of the Electricity Act 1989 to install and keep installed above ground an electric line of a naminal voltage of less than 132 kilovolts. The Form should be sent **in triplicate** to each District/Borough Council in whose area the proposed development would be situated.

DETAILS OF APPLICANT

Name: East Midlands Electricity plc

Address: Sleaford Road
BOSTON
Lincs

Postcode: PE21 8BR

Telephone Number: 0205 365181

PART I

East Midlands Electricity plc Application Number EM121/21/95290 Date 19 April 1993

To the Chief Executive Planning Department Council South Holland District Council
Priory Road
SPALDING

Dear Sir

Electricity Act 1989

Application is being made to the Secretary of State for Energy for his consent to the development described overleaf. The Secretary of State will at the same time be requested to direct that planning permission for this development shall be deemed to be granted. The consent and the direction may be given subject to conditions.

To assist the Secretary of State to determine the application the District/Borough Council is requested to return to me two copies of this Form with Part I Certificate and Part II completed and signed.

Department of the Environment Circular 14/90 (Welsh Office Circular 20/90) [Department of Energy Circular 1/90] describes this procedure and the reason for it.

Yours faithfully
For and on behalf of East Midlands Electricity plc.

OFFICE COPY

D. Tuley.

(D A Tuley)
Designation. Planning Engineer

CERTIFICATE

(To be completed by or on behalf of the District/Borough Council)

The District/Borough Council

(i) object on the grounds set out below/have no objection to make to the development described overleaf.*

(ii) request/do not request that a public inquiry be held pursuant to paragraph 2 of Schedule 8 to the Electricity Act 1989 before the Secretary of State reaches his decision on the application.*

Date Signed

*Delete as appropriate

Designation

On behalf of the District/Borough Council

(Reasons for objections)

PARTICULARS OF PROPOSED DEVELOPMENT AND REPRESENTATIONS

(To be completed by East Midlands Electricity plc)

Application is being made:

(a) for consent under section 37 of the Electricity Act 1989 to install or keep installed an electric line above ground;

(b) for a direction under section 90(2) of the Town and Country Planning Act 1990 that planning permission for the proposed development be deemed to be granted.

1. Particulars of proposed development. (These particulars should be accompanied by such plans as may be necessary to enable the local planning authority to identify the land affected by the proposals and to appreciate the nature and extent of the proposed development and by a copy of the environment statement if the applicant has prepared one.)

To erect the proposed 11,000 volt overhead line on wooden poles in the Parish of Crowland with a tolerance of 30m either side of the route shown on the attached plan.

2. Particulars of any representations of objections which have been made to East Midlands Electricity plc.

3. Particulars of the applicant's compliance with his duty under paragraph 1 of Schedule 9 to the Electricity Act 1989.

East Midlands Electricity plc consider that the proposed overhead line will not have any significant impact on the surrounding landscape, and that due regard has been paid to their obligations under Schedule 9.

Date 19 April 19 93 For and on behalf of East Midlands Electricity plc.

Signed D. Tuley. (D A Tuley) Designation Planning Engineer

Note: *This Part to be completed, dated and signed before submitting to the local planning authority.*

East Midlands Electricity plc Application Number EM121/21/95290

(Application dated 19 April 1993)

PART II—INFORMATION AND OBSERVATION

(To be completed by the District/Borough Council)

Planning Reference Number H02/0348/93.

1. Names of interested parties consulted about the proposals with details of any observations received.

2. Particulars of any representations which have been made to the local planning authority objecting to the proposals.

3. Have any general or specific restrictions been imposed by any authority on development of the land affected by the proposed development?

BRIAN SMITH Dip TP MRTPI
Director of Planning & Building Control Services
Planning & Building Control Department,
Council Offices,
Priory Road, Spalding,
Lincolnshire. PE11 2XE

Telephone: (0775) 761161
Fax: (0775) 710772

SOUTH HOLLAND DISTRICT COUNCIL

Application no: H02/0348/93

Applicant: East Midlands Electricity plc
Sleaford Road
Boston
Lincs
PE21 8BR

Agent: East Midlands Electricity p
Sleaford Road
Boston
Lincs
PE21 8BR

Description: Proposed 11,000 volt overhead line

Location: Parish of Crowland

Type: ELECTRICITY

APPLICATION DETERMINED BY SECRETARY OF STATE - SUMMARY OF DECISION

Planning permission has been granted by the Secretary of State, or is deemed to have been granted, on conditions set out below or attached.

1 The development to which this permission relates shall be begun not later than the expiration of five years beginning with the date hereof.
Reason: To comply with the provisions of Section 91(1) of the 1990 Act.

2 The Company shall dismantle & remove from the site any redundant lines & apparatus within 6 months from the date of commissioning of the lines
Reason: To restore the land as far as practicable to its condition before the redundant lines and apparatus were installed.

S. Holland 62

Department of Trade and Industry
Electricity Division
1 Palace Street
London SW1E 5HE

Fax No.	071 834 3771
Switchboard	071 238 3000
Direct Line	071 238 3634/3711

The Secretary
East Midlands Electricity plc
Boston

Dear Sir

Our Reference OL/266/2376

Date 24 JUN 1993

OVERHEAD LINES
ELECTRICITY ACT 1989
TOWN AND COUNTRY PLANNING ACT 1990.

With reference to the application particulars of which are specified below, I am directed by the Secretary of State to inform you that consent is hereby granted pursuant to section 37(1) of the Electricity Act 1989 ("the 1989 Act") to the installing above ground of electric lines ("the lines") particulars of which are specified below.

Pursuant to section 37(3) of the 1989 Act this consent is given subject to the following conditions:

1. The Secretary of State may review this consent at any time after a period of five years from the date hereof, and upon such review, after giving all persons concerned an opportunity of being heard, he may vary or revoke his consent.

2. If the Secretary of State revokes this consent the lines shall be removed within such period as the Secretary of State may direct.

Pursuant to section 90(2) of the Town and Country Planning Act 1990 ("the 1990 Act") the Secretary of State hereby directs that planning permission for the development shall be deemed to be granted subject to the following condition(s):

1. The development to which this permission relates shall be begun not later than the expiration of five years begining with the date hereof.

Reason: To comply with the provisions of section 91 (1) of the 1990 Act.

2. The Company shall dismantle and remove from the site any redundant lines and apparatus within six months from the date of commissioning of the lines.

Reason: To restore the land as far as practicable to its condition before the redundant lines and apparatus were installed.

PLANNING AUTHORITY REFERENCE: HO2/0348/93

APPLICANT COMPANY: East Midlands Electricity plc

DATE AND REFERENCE OF APPLICATION: 5 May 1993 EM 21/121-95290

PARTICULARS OF OVERHEAD LINES:

Situated in the Parish of Crowland

Route as indicated on Map No 93/95290 or within a distance not exceeding 30 metres on either side thereof.

Voltage 11,000

Yours faithfully

D. R. JOHNSON

Authorised by the Secretary of State


THORNEY CP
NEWBOROUGH CP
BOROUGH FEN CP
CROWLAND
CROWLAND CP
WEST LINCS DISTRICT
EXISTING FEEDER (NEWBOROUGH)
EXISTING FEEDER (DEEPINGS)
S.H.D.C. PLANNING DEPT
RECEIVED
-2 JUN 1993

East Midlands Electricity PLC

EAST LINCOLNSHIRE DISTRICT

Title Crowland / Deeping - New Feeder

	EXISTING	PROPOSED	TO BE DISMANTLED
Overhead Lines Shown	33 kv 11 kv LV		
Underground Cables Shown	33 kv 11 kv LV		
Transformers Shown	G.M.T. P.M.T.		

Ord Sheet No. TF 2211/2411 Scale 1:2500 Drawn A.E.W.

Based upon the Ordnance Survey with the sanction of the Controller of H.M. Stationery Office CROWN COPYRIGHT RESERVED.

Scheme No. 96290.

Drg. No. 96/96290.

Date 19/6/96.

Ref.

SOUTH HOLLAND D.C.
PLANNING
05
REF 346/93

3 x 4core 7/.428 Cu

No 602 ROSE VILLA

Elm Farm

Deeping Fen

Crowland Common

RE SITE P.M.T.

River Welland

150 A.C.S.R.

Crowland fodder lots

Crowland Low Wash

3 x 4core 7/.428 Cu

No 603 ROSE FARM

Broadbank

RE SITE P.M.T.

No 603A FARM COTTAGE

3 x 4core 7/.428 Cu