

Online Comment

Application H02-0378-16
Location 59 Broadway Crowland Spalding PE6 0BH
Proposal Details of contaminated land (Condition 3, parts i, ii and iii of H02-0147-15)

Name J Reith
Address Environmental Health Technician Safety and Environment

Date Submitted 27-05-16
For/Against Comments

I have considered all of the documents submitted with this application.
The information provided is sufficient to discharge parts i - iii of the contaminated land condition, but part iv cannot be discharged until we have been provided with a satisfactory verification report.

Due to concerns that there may still be hydrocarbon sources on site all recommendations within the remedial method statement by EPS Ref: UK14.1470 dated April 2016 must be adhered to.

I would ask that all construction workers operating at the site are made aware of Appendix A 'Method statement for Watching Brief and Dealing with Unexpected Contamination'.

A copy of the remedial method statement report has been forwarded to the Building Control Department for their information.

I require evidence that the recommendations within the remedial method statement have been followed and therefore a verification report must be submitted in due course