

## Online Comment

**Application** H02-0511-25  
**Location** Land off Postland Road Crowland  
**Proposal** Proposed development of 9 Dwellings

---

**Name** Diane Gordon  
**Address** SHDC Environmental Protection

**Date Submitted** 17-06-25  
**For/Against** Comments

the noise impact assessment NIA 11796-24-12035-v2 makes recommendations regarding attenuation measures for plots 5 and 6. i would recommend that these are included within the specifications for enhanced glazing for the habitable rooms in plot 5 facing the current jj cars premises. boundary treatment to 5 and 6 should include a 2m accoustic grade fencing as opposed to the proposed 1.8m, in order to reduce any potential noise impact on these residential properties to an acceptable level