



## Planning Application – Anglian Water Objection

If you would like to discuss any of the points in this document please contact us on 03450 263 912 or email [planningliaison@anglianwater.co.uk](mailto:planningliaison@anglianwater.co.uk).

AW Site Reference: 225890/1/0228004

Local Planning Authority: South Holland District

Site: Land off Postland Road  
Crowland

Proposal: Proposed development of 9  
Dwellings

Planning application: H02-0511-25

**Prepared by:** Pre-Development Team

**Date:** 5 June 2025

### ASSETS

#### Section 1 - Assets Affected

Our records show that there are no assets owned by Anglian Water or those subject to an adoption agreement within the development site boundary.

### WASTEWATER SERVICES

#### Section 2 - Wastewater Treatment

**Anglian Water OBJECTS to the proposed development under Planning Application H02-0511-25 due to the intended connection to the public foul drainage network.** This site is located within the catchment of the Crowland Water Recycling Centre (WRC), which currently lacks the capacity to accommodate the additional flows that would be generated by the proposed development. Anglian Water has determined that the site is unsustainable due to the associated environmental risk and the increased discharge rates, which could lead to a deterioration in water quality and an unacceptable risk of breaching environmental legislation at Crowland WRC.

Considering these concerns, we recommend that planning permission be refused on the grounds of insufficient infrastructure capacity and to prevent environmental harm. Anglian Water collaborates with local planning authorities across the region to identify sustainable locations for future development, taking into account infrastructure capacity as part of the development plan processes. We also work closely with our regulators to identify opportunities for future growth investment. At present, no funding has been allocated at this Water Recycling Centre (WRC) for AMP 7 (2020- 2025) or AMP 8 (2025-2030). However, we may seek to promote investment through our future business plans.

### Section 3 - Used Water Network

This response has been based on the following submitted documents:

DRAINAGE STATEMENT REV P2 MAY 2025

Drawing no. 12899-WMS-ZZ-XX-T-C-39201-S8-P2 MARCH 2025

The sewerage system at present has available capacity for these flows. However as advised above, any connection into our foul network from the proposed development will contribute to pollution and deterioration of the watercourse via the WRC. As stated in the objection above, the receiving WRC cannot accommodate additional flows. If LPA is minded to grant approval despite of our WRC objection, the developer will need to serve notice under Section 106 of the Water Industry Act 1991. We will then advise them of the most suitable point of connection.

1. INFORMATIVE - Notification of intention to connect to the public sewer under S106 of the Water Industry Act Approval and consent will be required by Anglian Water, under the Water Industry Act 1991. Contact Development Services Team 0345 606 6087 Option 2. 2. INFORMATIVE - Protection of existing assets - A public sewer is shown on record plans within the land identified for the proposed development. It appears that development proposals will affect existing public sewers. It is recommended that the applicant contacts Anglian Water Development Services Team for further advice on this matter. Building over existing public sewers will not be permitted (without agreement) from Anglian Water. 3. INFORMATIVE - Building near to a public sewer - No building will be permitted within the statutory easement width of 3 metres from the pipeline without agreement from Anglian Water. Please contact Development Services Team on 0345 606 6087 Option 2. 4. INFORMATIVE: The developer should note that the site drainage details submitted have not been approved for the purposes of adoption. If the developer wishes to have the sewers included in a sewer adoption agreement with Anglian Water (under Sections 104 of the Water Industry Act 1991), they should contact our Development Services Team on 0345 606 6087 Option 2 at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with Sewers for Adoption guide for developers, as supplemented by Anglian Water's requirements.

### Section 4 - Surface Water Disposal

The preferred method of surface water disposal would be to a sustainable drainage system (SuDS) with connection to sewer seen as the last option. Building Regulations (part H) on Drainage and Waste Disposal for England includes a surface water drainage hierarchy, with infiltration on site as the preferred disposal option, followed by discharge to watercourse and then connection to a sewer.

From the details submitted to support the planning application the proposed method of surface water management does not relate to Anglian Water operated assets. The submitted document DRAINAGE STATEMENT REV P2 MAY 2025 proposes to discharge surface water from the development to an existing watercourse. As such, we are unable to provide comments in the suitability of the surface water management. The Local Planning Authority should seek the advice of the Lead Local Flood Authority or the Internal Drainage Board. The Environment Agency should be consulted if the drainage system directly or indirectly involves the discharge of water into a watercourse. Should the proposed method of surface water management change to include interaction with Anglian Water operated assets, we would wish to be re-consulted to ensure that an effective surface water drainage strategy is prepared and implemented.