21ES421
Hospital
Deeping St Nicholas
ABSD

CB20 21D0123
HOSPITAL FARM
DEEPING ST NICHOLAS

185 AL/CCL CWE

150 XLPE

185 AL/CCL CWE

Deeping St Nicholas
County Primary School

Lonsdale Farm

Hospital Farm

300 AL/CCL CWE

95 AL/CCL CWE

150 XLPE

185 AL/CCL CWE

185 PIAS

Bluehouse Farm

PROPOSED 315 KVA
PACKAGE S/STN

Level Crossing

Level Crossing

Level Crossing

Ⓐ - Ⓑ
STREET LIGHTING CABLE ONLY

SWING STAYS TO
TERMINATE LINE

BA20 21E5947
CHAPPELL ROAD
DEEPING ST NICHOLAS

Allotment Gardens

Sewage Works

Filter Bed

Deeping Fen

RESITE

95 AL/CCL CWE

BA20 21E0999
BIRCHS DEEPING
ST NICHOLAS

3x150 ACSR

H.V. 10m OVERDRAIN

10m OVERDRAIN

21ES440
Common Lowe Farm
Crowland
ABSD
22

Deeping Fen

DETERMINED
PLAN

SOUTH HOLLAND DC
HOUSING & PLANNING
24 MAY 2000
Ref: 0656/00

EXISTING OVERHEAD LINE
EXISTING UNDERGROUND CABLE
PROPOSED OVERHEAD LINE
PROPOSED UNDERGROUND CABLE
OVERHEAD LINE TO BE DISMANTLED

DEEPING FEEDER No.4
N.02962
A.T./B.E.L. 12/05/00

This plan is based upon the ordnance survey map by East Midlands Electricity, a division of PowerGen Energy plc with the sanction of the Controller of H.M. Stationery Office. Crown Copyright Reserved. Subject to any specific exceptions this copy must not be copied without the prior permission of the copyright owner. Any information provided by East Midlands Electricity is copyright and may not be reproduced in any form without the written permission of East Midlands Electricity.

Scale 1:2500 /LV, 11kV, 33kV, 25kV, 132kV	TF20641412 (520648,314121)	
Sheet 1 of 1	Bryan Lee	11/04/2000