

Online Comment

Application H02-0830-20
Location Land at the junction of Broadway/ Peterborough Road Crowland
Proposal Erection of 3 bed detached dwelling with attached garage

Name Sue Armour
Address Environmental Protection Officer SHDC PE11 2XE

Date Submitted 17-12-20
For/Against Comments

I have reviewed the Morton & Hall Consulting Limited Ground investigation report ref H6249/RAM/sg and withdraw my previous comments on this basis. No made ground was encountered across the site, and as such I request that the following informative be placed on any permission granted:

In the event that contamination is found at any time when carrying out the approved development that was not previously identified it must be reported immediately to Environmental Health. An investigation and risk assessment must be undertaken in accordance with details to be agreed with Environmental Health. Where remediation is necessary, a remediation scheme must be submitted to and approved in writing by Environmental Health. Following completion of measures identified in the approved remediation scheme a verification report shall be submitted to and approved by Environmental Health.