Online Comment

Application	H02-0898-16
Location	DECOY FARM SPALDING ROAD CROWLAND
Proposal	Proposed standby electricity generation plant in portal framed building including ancillary equipment

---

Name	Steve Branson
Address	Environmental Health Technician Safety and Environment

Date Submitted	19-09-16
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background level by more than 5 dB(A) when measured as a 15 minute LAeq at any residential boundary not within the applicant's ownership.