

Online Comment

Application H02-0899-16
Location DECOY FARM SPALDING ROAD CROWLAND
Proposal Proposed standby electricity generation plant in portal framed building, including ancillary equipment

Name Steve Branson
Address Environmental Health Technician Safety and Environment

Date Submitted 19-09-16
For/Against Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background level by more than 5 dB(A) when measured as a 15 minute LAeq at any residential boundary not within the applicant's ownership.