Online Comment

Application	H02-0915-15
Location	Decoy Farm Spalding Road Crowland PE6 0LX
Proposal	Installation of six GRP transformer cabinets in white

---

Name	Steve Branson
Address	Environmental Health Technician Safety and Environment
Date Submitted	11-11-15
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background level by more than 5dB(A)when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.