



Jordan Finding
JAF Estates Ltd
7
Pembroke Grove
Peterborough
United Kingdom
PE6 7LG

Anglian Water Services Limited
Development Services
PO Box 495
Huntingdon
PE29 6YY
0345 60 66 087
developmentservices@anglianwater.co.uk

20 September 2021

Dear Jordan

Section 106 Water Industry Act 1991 – Sewer Connection

Application Reference: ALD-0130812

Site: 10 Harrington Drive, Crowland, Peterborough

Thank you for your application for a sewer connection to serve the above premises.

I can confirm that Anglian Water has no objection to X1 foul water connection and X 1 Surface water connection onto the existing foul water sewer in Harrington Road via Junction insertion as per drawing number 101

Please note that our approval is based upon the public sewer records. No physical surveys have been carried out by Anglian Water to ascertain the existence or position of the sewer(s) to which you are intending to connect. The actual position of all apparatus should be established by trial holes. On this occasion we have decided not to exercise our right under section 107(1) Water Industry Act 1991 to undertake the sewer connection ourselves.

We will inspect work carried out on the public sewer and we may have to issue permits to your contractor. Please follow the necessary steps on InFlow to arrange an appointment for a Developer Services Representative to visit site. Alternatively, a visit can be arranged by contacting Nigel Key directly on 07736175764 giving 5 working days notice of when the work on the public sewer will commence.

The property will be billed for sewerage charges three months from the date of this approval letter if we have not had notification of the connection date or that the connection is not proceeding.

An infrastructure charge will also be applicable in addition to the connection fee. The sewerage infrastructure charge for 2021/22 is set at £573.00. This will be billed by the water company either before or shortly after the connection has taken place. For further information regarding this charge, please see the Development Services Charging Arrangements document on our [website](#).

Please be advised that whilst this letter confirms that we have no objection to the type of connection proposed, it should not be issued to the Planning Authority as proof that a drainage strategy has been agreed with Anglian Water. If we have placed a drainage condition at the planning stage, you are still required to comply with any stipulations we have made regarding the point of connection or discharge rates before we will confirm to the Planning Authority that the condition has been satisfied.

If your application is for a non-household property then please be aware, at the point of connection, you will need to have selected a retailer. To find out more and for guidance on how to select a retailer go to www.Open-water.org.uk/Customers/.

Finally, please be aware of your obligation under the Construction (Design and Management)

Regulations 2015, more information can be found at www.hse.gov.uk.

Yours sincerely,

Tracey Sutton

Development Services