THIS DRAWING REMAINS THE PROPERTY OF PUSH POWER AND MUST NOT BE REPRODUCED, COPIED, OR HANDED OVER TO A THIRD PARTY WITHOUT PRIOR WRITTEN CONSENT. UNCONTROLLED COPY IF PRINTED. DO NOT SCALE.



Details:

PV:

DC:
Module Type: Aiko (660 W)
Module Quantity: 16,896
DC Capacity: 11,151.36 kW

AC:
Inverter Type: SG350HX (352 kVA @ 30 °C)
Inverter Quantity: 24
AC Capacity: 8,448.00 kVA

DC/AC Ratio: 1.32

STS:
STS Type: MV4480-LV (4,928 kVA @ 30 °C)
STS Quantity: 2

STS Capacity: 9,856 kVA

Key:

- Parcel number
- OHL
- Fenceline
- PV module
- Proposed HV Cable Route
- Existing HV Cable Route
- STS Units
- Existing Access Track
- Proposed Access Track
- Proposed Private Substation
- Proposed Comms Cabinet
- Proposed Pad Mount Transformer
- 40ft Container
- 20ft Container
- Existing Customer Substation
- Existing DNO Substation
- Existing 11 kV Pad Mount Transformer
- Existing PV module

Notes:

- Access track shown for information only and is subject to a separate application

DRAFT

Rev	Amendment	Drawn	Checked	Date
-	-	-	-	-
02	TOPO added, Equipment changed	BK	AR	18.11.25
01	Fenceline, STS location update	BK	SGB	14.05.25

push
Unit 1-2 Tollgate East, Colchester, CO3 8AB
Tel: 01206 203253
www.pushpower.co.uk

Drawing title:	Site Layout Plan		
Site name:	Decoy Farm 2		
Site address:	Decoy Farm, Peterborough, PE6 0LX		
Drawn by:	BK	Checked by: SGB	Scale: 1:2000 @ A1
Drawing number:	PPP027.301.02		Date: 25.04.2025