LIGHTNING PROTECTION TO BE FITTED AS PER SCOPE BY TONY HAGGIS.

LINE SURVEY/PROFILE TO BE CARRIED OUT.

Cattle Grid

Drain

0.025CADCu (11kV)

0.04SCA (11kV)

DIVERT 0.025 CAD CU

3 x 50 ACSR (HV)

BA20 21E1080
VICTORIA FARM
CROWLAND

Victoria Farm

Compleves Farm

BA20 21E0043
WASH P/S
CROWLAND

15m VERTICAL CLEARANCE OVER BANK

ERECT NEW STAY ADJACENT TO FENCELINE

SLACK SPAN TAKE – OFF

A – B	3 x 50 ACSR (HV)
C – D	3 x 50 BLX (HV)

3 x 50mm² BLX

10m VERTICAL CLEARANCE OVER BANKS

The Gull

21ES489
Cowbit
Wash Bank
ABSD

BA20 21E0594
GULL HOUSE
CROWLAND

Welland

Crowland Fodder Lots

BA10 21E0025
CLOOT HOUSE
CROWLAND

Cloot House

Pond

EXISTING HV OVERHEAD LINE

PROPOSED HV OVERHEAD LINE

HV OVERHEAD LINE TO BE DISMANTLED

EXISTING UNDERGROUND CABLE

DETERMINED PLAN

EM/R/62.

CROWLAND

WELLAND BANK
11KV Overhead line

N.00096

Tom Scott 1/11/02

Scale 1:1250 /LV, 11kV, 33kV, 25kV, 132kV	TF24951472 (524952,314724)	
Sheet 1 of 1	Gill Holmes	01/11/2002