Online Comment

Application	H03-0175-26
Location	Park Farm Banks Drove Deeping St Nicholas PE11 3BJ
Proposal	Demolition of agricultural building and erection of grain store and associated infrastructure

---

Name	Oliver Abrams
Address	SHDC Environmental Protection Officer
Date Submitted	28-04-26
For/Against	Comments

I have reviewed Woodcock and Wilson Ltd Fan Noise Data, Ref: Q54932c, Dated: 14/04/2026. Provided the fans are installed as proposed on the current site plans with the 6mm thick casing, noise levels should be within an acceptable range for the nearest residential property which is Park Farm Cottage.