Online Comment

Application	H03-0410-16
Location	Land south of Counter Drain Drove Tongue End Spalding PE11 3JJ
Proposal	Erection of an anaerobic digestion plant and ancillary services

---

Name	Steve Branson
Address	Environmental Health Technician Safety and Environment

Date Submitted	11-11-16
For/Against	Comments

No objection in principle however I would request a working hours restriction and the following noise condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.