

Online Comment

Application H03-0908-19
Location Caultons Field west: Littleworth Drove Deeping St Nicholas PE11 3AE
Proposal Details of Interpretive Report on Ground Investigation Report (Part ii of Condition 11 of H03-0331-16)

Name Sue Armour
Address Environmental Protection Officer SHDC PE11 2XE

Date Submitted 21-01-20
For/Against Comments

I have reviewed the Nicholas Colton Group report ref G19102-LR2 dated 2nd January 2020 and recommend discharge of part ii of condition 11 of H03-0331-16.

The proposals for remedial action are acceptable in principle, however there in order to discharge part iii more detail is required. With respect to the soil removal and subsequent encapsulation, how will this be validated? How will the applicant show that the replacement soil is suitable for use?

With respect to the ground gas, CS₂ is acceptable, however the design proposals are required.