File Note confirming Doors will be Anthracite Grey, Plot Schedule with Finished Floor Levels included, and clarification that Finished Floor levels comply with Outline Condition 15 (H03-0161-17).

RE: H03-1044-24 - Home Farm, Deeping St Nicholas

LR [redacted]@lincsdesignconsulta

Reply | Reply All | Forward

To Simmons, Maxine
Cc Ricky Newton

Thu 30/01/2025 15:26

You replied to this message on 30/01/2025 17:10.

We sent you safe versions of your files
Outlook item

LDC4244 Planning Amendment Form.pdf
497 KB

unless you recognise the sender and know the content is safe. If you believe it is suspicious please forward to Suspicious.Emails@pspsl.co.uk and delete the email.

Hi Maxine,

Please find attached a plot schedule which contains floor levels, do you need us to submit an amendment form for this?

Also, our client has confirmed doors will be anthracite / dark grey (or similar)

Kind regards,

[redacted] BSc (Hons) ACIAT
Graduate Architectural Technologist

T : 01507 611155
www.lincsdesignconsultancy.co.uk

From: Simmons, Maxine <Maxine.Simmons@sholland.gov.uk>
Sent: 29 January 2025 12:03
To: [redacted]@lincsdesignconsultancy.co.uk>
Subject: RE: H03-1044-24 - Home Farm, Deeping St Nicholas

Hi Maxine,

I can confirm that all finished floor levels are set at least 300mm above AOD.

Those with levels set at 1.900, are in an area where existing levels are between 1.500 and 1.600

Kind regards,

[redacted] BSc (Hons) ACIAT
Graduate Architectural Technologist

T : 01507 611155
www.lincsdesignconsultancy.co.uk