Online Comment

Application	H03-1063-20
Location	POPLAR FARM MAIN ROAD DEEPING ST NICHOLAS PE11 3DJ
Proposal	Proposed Industrial Building (B2 Use) and Storage Building (B8 Use)

Name	Steve Branson
Address	South Holland District Council Priory Road
Date Submitted	03-01-21
For/Against	Comments

No objection but would wish to attach the following condition;
Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.