Online Comment

Application	H03-1151-18
Location	Caultons Field West of Littleworth Drove Deeping St Nicholas
Proposal	Erection of 66 dwellings and associated works - outline approval H03-0331-16

Name	Ruth Dowling
Address	Building COntrol South Holland District Council

Date Submitted	17-01-19
For/Against	Comments

Where private Drives exist provision should be made for Fire Appliances and Rubbish Trucks, Rubbish should not be carried no further than 30m from the property.