Online Comment

Application	H04-0773-20
Location	DAVE COOK ENGINEERING QUADRING ROAD DONINGTON PE11 4TB
Proposal	Details of Condition 7 of H04-0894-17 relating to contamination

---

Name	Sue Armour
Address	Environmental Protection Officer SHDC PE11 2XE
Date Submitted	22-10-20
For/Against	Comments

Ground Engineering's statement does not constitute a remediation method statement. I appreciate that at this location a very simple statement is required, however it does need more information than has been submitted.
Will the specialist contractor be on site whilst all of the earth works are undertaken? This seems unlikely to me, so the RMS should be a document used on site by all ground workers. Will the site foreman walk the site each morning? Or will site operatives stop and hand pick should they see something? How will they record that? Do they need to record it? What will they submit for validation, and who will do that? A nill return would still be needed.