Online Comment

Application	H04-1200-17
Location	Land adjacent: 20 20 Town Dam Lane Donington PE11 4TP
Proposal	Erection of single-storey dwelling - retrospective

Name	Black Sluice Internal Drainage Board
Address	Station Road Swineshead Boston PE20 3PW

Date Submitted	09-01-18
For/Against	Comments

The applicant has indicated soakaways as the means of surface water disposal. If this is the case, then provided the applicant has carried out the requisite tests under BRE Digest 365 to prove positive that soakaways are suitable, then the Board has no further comment. However, if tests prove that soakaways are unsuitable, then the applicant must submit full details of an alternative surface water disposal scheme to the planning authority for their consideration, and have approval granted by that authority in writing, prior to the completion of the works.