# Online Comment

| | |
|---|---|
| **Application** | H04-1282-16 |
| **Location** | 18 Barnes Road Donington Spalding PE11 4UW |
| **Proposal** | Residential development - outline permission H04-0409-16 |

---

| | |
|---|---|
| **Name** | Black Sluice Internal Drainage Board |
| **Address** | Station Road Swineshead Boston PE20 3PW |

| | |
|---|---|
| **Date Submitted** | 07-02-17 |
| **For/Against** | Comments |

The Board has the following comments:

1. The applicant has now indicated the use of rainwater harvesting, with a declared restricted discharge of 1 litre/sec. The question is discharge to where? To soakaway? To a watercourse?
2. If the discharge is an overflow to soakaway, then any soakaways or infiltration systems should be designed and proved in accordance with BRE Digest 365 or other approved code.
3. If the discharge is to a watercourse, then this will require the prior written consent of the Board.