From: Remway Design | Jason Wilson
To: Meachen, Tracey
Subject: RE: H04-1282-16 : 18 Barnes Road
Date: 07 February 2017 13:23:55

This message originated from outside your organization

It discharges to an overflow soakaway at a rate of 1L/sec in accordance with BRE Digest 365 Tracey

Many thanks and best regards,

Jason Wilson
Remway Design Ltd **t:** 01775 768 921

"This message is intended solely for the use of the individual or organisation to whom it is addressed. It may contain privileged or confidential information which should not be distributed further without express permission of the sender.Remway Design Ltd accepts no responsibility for loss or damage arising from its use, including damage from virus."

SAVE PAPER - Please do not print this e-mail unless absolutely necessary

From: Meachen, Tracey [mailto:TMeachen@sholland.gov.uk]
Sent: 07 February 2017 12:31
To: 'Remway Design | Jason Wilson'
Subject: H04-1282-16 : 18 Barnes Road

Hi Jason,

I am forwarding the comments from Black Sluice IDB.

The Board has the following comments: 1. The applicant has now indicated the use of rainwater harvesting, with a declared restricted discharge of 1 litre/sec. The question is discharge to where? To soakaway? To a watercourse? 2. If the discharge is an overflow to soakaway, then any soakaways or infiltration systems should be designed and proved in accordance with BRE Digest 365 or other approved code. 3. If the discharge is to a watercourse, then this will require the prior written consent of the Board.

Regards

Tracey Meachen | Planning Officer | **South Holland District Council**
DDI: 01775 764607 |
www.sholland.gov.uk