

DONINGTON

FRUITEX 11kV Rebuild

K.01272 14/10/03

SWING STAY TO FIT
NEW ANGLE

MINIMUM 9.0m DISTANCE
FROM EDGE OF DRAIN TO
OVERHEAD CONDUCTORS

3 x 50 ACSR

185AL (LV,decom)

SA
E

40ACSR (11kV)

Depot

185 XLPE (HV)

40ACSR (11kV)

REMOVE PMT
21E5485
FRUITEX
DONINGTON

120CNE (LV)

185 Al/Cu CNE (LV)

INSTALL 200 KVA PADMOUNT
FRUITEX
DONINGTON
NEW NUMBER 21D0264

185 XLPE (HV)

35Al/CuCNE (LV)

95Al/CuCNE (LV)

95Al/CuCNE (LV)

35Al/CuCNE (LV,decom)

RE-SITE PMT
21E6881
ORANGE
DONINGTON
NEW NUMBER 21E0266

3.359ha
8.30

0.1SCA (11kV)

M P 52 1/2

35CNE 1ph (LV)

Drain

Pond 3886
453ha
1-12

Empl/119

EXISTING OVERHEAD LINE
EXISTING UNDERGROUND CABLE
PROPOSED OVERHEAD LINE
PROPOSED UNDERGROUND CABLE
OVERHEAD LINE TO BE DISMANTLED

SHDC
Planning & Development

29 OCT 2003

Ref

1308/03