_planningadvice

From: Watkinson, Gregory
Sent: 29 May 2020 12:16
To: _planningadvice
Subject: FW: Church of S Mary Fleet H05-0291-20

Hi

Please can this email be scanned to H05-0291-20 as 6SUP, entitled 'email confirming use of batten roll seams'

Many thanks.

Kind regards,
Greg

Gregory Watkinson | Conservation Officer | **South Holland District Council**
DDI: 01775 764560 | GWatkinson@sholland.gov.uk | **www.sholland.gov.uk**

Please note that any informal officer opinion expressed by this email is without prejudice and is not binding on the Council during the consideration of any formal application.



From: Tim Benton <tim_benton@btopenworld.com>
Sent: 29 May 2020 12:06
To: Watkinson, Gregory <GWatkinson@sholland.gov.uk>
Subject: Church of S Mary Fleet H05-0291-20

This message originated from outside your organization

Good Afternoon

Further to our telephone conversation I confirm that the tern coated stainless steel is to be laid with rounded battens to more closely resemble the appearance of lead sheets.

Regards

Tim Benton Architect
33 Northgate Sleaford
Lincolnshire NG34 7BX

T 01529 304524
M 07966 398541