Meachen, Tracey

From: Meachen, Tracey
Sent: 17 August 2011 12:28
To: 'Remway Design - Jason Wilson'
Subject: RE: Willows Tea Rooms Amendments

Thank you for the new plans Jason. However, I have made the following observations:
- the fascia should stop in line with the window frame and not continue beyond the sides.
- there should be no cornice bracket or detail to the side of the fascia.
- there is no cornice detail provided above the fascia, which should also protrude outwards beyond the front of the fascia.
- there should be no pilaster plain or otherwise, just the windows with fascia and cornice above.

Hope this helps.

regards

Tracey

From: Remway Design - Jason Wilson [mailto:jason@remwaydesign.co.uk]
Sent: 16 August 2011 11:32
To: Meachen, Tracey
Cc: 'Matt Pitts'; 'Martin Hefford'
Subject: *Willows Tea Rooms Amendments*

Tracey,

Please find attached amended design drawings for the Willows Shop front.

Let me know if the drawings are acceptable so we may move forward.

Many thanks,

Best Regards,

Jason

SAVE PAPER - Please do not print this e-mail unless absolutely necessary

---

This email has been scanned by the MessageLabs Email Security System.



AMENDED PLAN
Ref. H05-0333-11/A1

Scale 1:10

Paper Size A1

SHDC
Planning & Development
18 AUG 2011
Ref: 0333-11.

DETERMINED PLAN

Rec'd 18.8.11.