

## Online Comment

**Application** H05-0459-20  
**Location** Land off Old Main Road Fleet Hargate Spalding  
**Proposal** Details of Conditions 3, 4, 6, 7, 8, 9, 11, 12, 14, 15, 18, 19, 20, 21, 22 and 23 of H05-1235-18.

---

**Name** Sue Armour  
**Address** Environmental Protection Officer SHDC PE11 2XE

**Date Submitted** 17-01-22  
**For/Against** Comments

I have reviewed the following documents:

- GeoDyne Letter report ref D37124/PK dated 25/9/20 'Re: Ground Gas Report - Old Main Road, Fleet Hargate'
- GeoDyne Letter report ref D37124/PK dated 28/9/20 'Re: Supplementary soil Sampling - Old Main Road, Fleet Hargate'

I am in general agreement with the findings and recommend discharge of part ii of condition 22 of H05-1235-18.

The Ground Gas Report sets out the general requirements for the ground gas protection measures recommended, however site specific details of the proposed ground gas protection measures and the proposed validation methods should be submitted in order to discharge part iii.