Online Comment

Application	H05-0612-20
Location	Thickpenny Produce Ltd. Bens Gate Fleet PE12 8PQ
Proposal	Erection of steel framed building for potato grading

---

Name	Steve Branson
Address	South Holland District Council Priory Road

Date Submitted	24-08-20
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5 dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.