

Our ref: 26_34332_P

28/01/2026

Your ref: H05-1060-25

Site Location: FLEETWOOD HOUSE NEW FEN
DROVE GEDNEY HILL SPALDING PE12 0PY

Summary of Proposal: Erection of a single storey detached garage and office space

Dear Sir/Madam,

Thank you for your consultation on the above application.

The site is within the Internal Drainage District (IDD) of the South Holland Internal Drainage Board (IDB) and therefore the Board's Byelaws apply. Whilst the Board's regulatory process (as set out under the Land Drainage Act 1991 and the Board's Byelaws) is separate from planning, the ability to implement a planning permission may be dependent on the granting of any required Land Drainage Consents.

The Board's Officers have reviewed the documents submitted in support of the above planning application. Officers have noted works which may require Land Drainage Consent from the Board as outlined in the table below and detailed overleaf. Please be aware of the potential for conflict between the planning process and the Board's regulatory regime.

Where consents are required, the Board strongly recommends that these are sought from the Board prior to determination of this planning application. The annexe at the end of this letter outlines the Board's regulatory function and how to apply for Land Drainage Consent.

Byelaw / Section of Act	Description	Requirement
Byelaw 3	Discharge of water to a watercourse (treated foul or surface water)	Consent may be required
Section 23, Land Drainage Act 1991	Alteration of a watercourse	Consent may be required
Byelaw 10	Works within 9 metres of a Board arterial watercourse	Not Applicable

Duncan Worth (Chairman)

Simon Bartlett (Vice-Chairman)

Marcus Coleman (Chief Executive)

Constituted by The Anglian Water Authority (South Holland Internal Drainage District) Order 1974,
Statutory Instrument 1974 No.1209. Reconstituted in 1993. Statutory Instrument 1993 No.453.

www.wlma.org.uk

Byelaw 3 (Surface Water)

I cannot see that the applicant has identified a drainage strategy for the site within their application. We recommend a drainage strategy is provided for the site. If the applicant proposes to discharge surface water to a watercourse, consent would be required under Byelaw 3.

The Board recommend that any discharge is in line with the [National standards for sustainable drainage systems \(SuDS\)](#) published in June 2025. Further to the National Standards for SuDS, the Board's policy is to restrict discharges to 2l/s/ha or annual average flood flow rate (QBar or QMed), whichever is higher.

Please note that any consent granted for the discharge of surface water is likely to be subject to a Surface Water Development Contribution fee (SWDC) as outlined within our [Development Control Charges and Fees](#).

Byelaw 3 (Treated Foul Water)

I note that the applicant has not indicated how they propose to dispose of foul water from the development. If the applicant proposes to discharge treated foul water to a watercourse, consent would be required under Byelaw 3. Please note that any consent granted for the discharge of treated foul water is likely to be subject to a Treated Foul Water Development Contribution fee (TFWDC) as outlined within our [Development Control Charges and Fees](#).

Section 23, Land Drainage Act 1991

I am not aware of any riparian owned/maintained watercourses within or adjacent to the site boundary, however this should be confirmed by the applicant. Should the applicant's proposals include works to alter a watercourse, or if works are proposed to alter a watercourse at any time in the future, consent would be required under the Land Drainage Act 1991 (and byelaw 4).

Byelaw 10

There are no Board arterial watercourses within or adjacent to the site boundary therefore Byelaw 10 does not apply.

Please see the supplementary information overleaf for further detail on the Board's policy and consenting process.

If, following review of our comments and supporting policy documents linked below, you wish to discuss any of the requirements I have raised, please contact the Board using the details at the head of this letter.

Yours sincerely,

Fern

Fern Crofts
Assistant Sustainable Development Officer
Water Management Alliance

How to Apply for Land Drainage Consent

To apply for Land Drainage Consent please complete an application form.

Application forms, application fees and 'Frequently Asked Questions' can be found on the 'Development & Consent' section of the Board's website, here: <https://wlma.org.uk/development-consent/>

For any additional help please call us on 01553 819600 or email planning@wlma.org.uk.

Byelaws

South Holland IDB Byelaws can be found via the following link:
https://www.wlma.org.uk/uploads/SHIDB_Byelaws.pdf

Mapping

Mapping of the district can be viewed via the following link (choose 'dynamic map' for interactive maps):
<https://wlma.org.uk/south-holland-idb/mapping/>

Planning and Byelaw Strategy

The Board's Planning and Byelaw Strategy seeks to provide:

- Guidance on how (and why) the Board will review and comment on planning applications.
- Information on the policies against which the Board will assess and determine applications.
- Guidance to riparian (waterside) landowners regarding watercourse maintenance.

Please see the Development and Consent pages on the Board's website via the following link:
<https://wlma.org.uk/development-consent/>

Arterial Watercourses

Maps on the Board's website show which watercourses are designated as Arterial Watercourses by the Board. You may also have heard these watercourses referred to as 'Main Drains' or 'Maintained Watercourses'. The designation is an acknowledgement by the Board that the watercourse is of arterial importance to the Internal Drainage District and as such will normally receive maintenance from the IDB using the Board's Permissive Powers. Although the Board opts to proactively maintain this arterial network, there is no change in the ownership or liability associated with the watercourse resulting from this designation.

Why we have commented on this application:

By engaging with the planning process the Board is seeking to:

- Reduce flood risk to communities within the Internal Drainage District
- Promote sustainable development in sustainable locations by supporting sound planning decisions in accordance with the National Planning Policy Framework (especially [Paragraph 167](#)) and the [National standards for sustainable drainage systems \(SuDS\)](#)
- Reduce the potential for conflict between the planning process and the Board's regulatory process.

For further information please refer to the Board's Planning and Byelaw Strategy.