# Online Comment

| | |
|---|---|
| **Application** | H05-1118-18 |
| **Location** | Land off Fleet Road Fleet Hargate Spalding |
| **Proposal** | Erection of 6 dwellings with means of access. |

---

| | |
|---|---|
| **Name** | Sue Armour |
| **Address** | Environmental Protection Officer SHDC |
| **Date Submitted** | 03-12-18 |
| **For/Against** | Comments |

I request the following condition be attached to any planning permission:
a)Investigate the site for landfill gas to the satisfaction of the LPA, to ascertain whether gas protection measures are required. Where measures are required the details shall be submitted to, and approved by, the LPA.
OR
b)The applicant shall install gas protection measures as a precautionary measure without first investigating the site. The details of these measures shall be submitted to, and approved by, the LPA.

c) For a) and b) all required measures shall be installed before the development is first occupied.