

Notes: This Form is for use in connection with an application for the Secretary of State for Energy's consent under **section 37** of the Electricity Act 1989 to install and keep installed above ground an electric line of a nominal voltage of less than 132 kilovolts. The Form should be sent **in triplicate** to each District/Borough Council in whose area the proposed development would be situated.

DETAILS OF APPLICANT

Name: East Midlands Electricity plc
Address: Tritton Road
Lincoln
Postcode: LN6 7RS
Telephone Number: 01522 684040

PART 1

East Midlands Electricity plc Application Number EM233/23/97012 Date 4 December 1995
To the Chief Executive Planning Department Council South Holland District

Dear Sir

Electricity Act 1989

Application is being made to the Secretary of State for Energy for his consent to the development described overleaf. The Secretary of State will at the same time be requested to direct that planning permission for this development shall be deemed to be granted. The consent and the direction may be given subject to conditions.

To assist the Secretary of State to determine the application the District/Borough Council is requested to return to me two copies of this Form with Part I Certificate and Part II completed and signed.

Department of the Environment Circular 14/90 (Welsh Office Circular 20/90)[Department of Energy Circular 1/90] describes this procedure and the reason for it.

Yours faithfully

For and on behalf of East Midlands Electricity plc.



D J Bushell
Designation: Project Manager

CERTIFICATE

(To be completed by or on behalf of the District/Borough Council)

The

District/Borough Council

- (i) object on the grounds set out below/have no objection to make to the development described overleaf.*
(ii) request/do not request that a public inquiry be held pursuant to paragraph 2 of Schedule 8 to the Electricity Act 1989 before the Secretary of State reaches his decision on the application.*

Date

Signed

* Delete as appropriate

Designation

On behalf of the
(Reasons for objections)

District/Borough Council

East Midlands Electricity plc Application Number

(Application dated 4 December 1995)

PART II - INFORMATION AND OBSERVATION

(To be completed by the District/Borough Council)

Planning Reference Number EM233/23/97012

1. Names of interested parties consulted about the proposals with details of any observations received.
2. Particulars of any representations which have been made to the local planning authority objecting to the proposals.
3. Have any general or specific restrictions been imposed by any authority on development of the land affected by the proposed development?

PARTICULARS OF PROPOSED DEVELOPMENT AND REPRESENTATIONS

(To be completed by East Midlands Electricity plc)

Application is being made:

- (a) for consent under section 37 of the Electricity Act 1989 to install or keep installed an electric line above ground;
- ~~(b) for a direction under section 90(2) of the Town and Country Planning Act 1990 that planning permission for the proposed development be deemed to be granted.~~

1. Particulars of proposed development. (These particulars should be accompanied by such plans as may be necessary to enable the local planning authority to identify the land affected by the proposals and to appreciate the nature and extent of the proposed development and by a copy of the environment statement if the applicant has prepared one.)

To erect the proposed 11,000 volt overhead line on wooden poles in the parish of Fleet with a tolerance of 30m either side of the route shown on the attached plan.

2. Particulars of any representations of objections which have been made to East Midlands Electricity plc.

3. Particulars of the applicant's compliance with his duty under paragraph 1 of Schedule 9 to the Electricity Act 1989.

ENVIRONMENTAL STATEMENT

This high voltage overhead line is to improve the supply voltage to two areas where at present statutory limits are not maintained. The properties in Hocklesgate and Little Marsh Lane, Fleet Fen are fed off long low voltage networks and increasing the line specification would not improve the matter.

The overall impact on the environment will be reduced as the additional 560 metres of high voltage line and some cable installation will facilitate the removal of 810 metres of low voltage line.

Date

For and on behalf of East Midlands Electricity plc

Signed



D J Bushell

Designation: Project Manager

Note: This Part to be completed, dated and signed before submitting to the local planning authority