Online Comment

Application	H06-0236-17
Location	Barn 1 and Barn 2 Bullocks Short Gate Gedney Fen Spalding PE12 0DG
Proposal	Conversion of barns into 2 dwellings

Name	J Reith
Address	Environmental Health Technician Safety and Environment

Date Submitted	24-03-17
For/Against	Comments

The Phase I & II Geo-Environmental Assessment by EPS Reference UK16-2451 dated 01 December 16 has identified some contamination issues.
The report had listed several recommendations in Section 8 as follows: a) clean soil cover system b) gas resistant membrane incorporated in floor system c) aluminium barrier pipework d)bunding of tanks e)Survey for asbestos containing materials f)how to deal with unexpected contamination g) construction workers on site.
I will require evidence in due course that these measures have been undertaken and request a full closure report. I therefore request part 4 of the contaminated land condition for this application.