

Online Comment

Application H06-0372-21
Location Tilsons Yard Black Barn Main Road Gedney Drove End PE12 9PA
Proposal Details of external materials, external boxes, gas flues & soil vent pipes, landscaping, foul & surface water disposal and scheme to deal with contamination (Conditions 2, 3, 4, 5 & 6 of H06-0463-21)

Name Sue Armour
Address Team Leader Environmental Protection SHDC

Date Submitted 22-05-23
For/Against Comments

I have reviewed the Goldfinch Environmental letter dated 23/6/21 and am in general agreement with the findings, which are to install basic gas protection measures. Validation in the form of site photos as the membrane is laid and delivery notes should be submitted to fully discharge the condition, but at this stage I can recommend discharge of parts i & ii of condition 6 of H06-0463-21