Online Comment

Application	H06-0569-18
Location	Adjacent: Linden House Churchgate Gedney PE12 0BZ
Proposal	Erection of detached dwelling

Name	Sue Armour
Address	Environmental Protection Officer South Holland District Council

Date Submitted	09-07-18
For/Against	Comments

I request the following condition:

a)Investigate the site for landfill gas to the satisfaction of the LPA, to ascertain whether gas protection measures are required. Where measures are required the details shall be submitted to, and approved by, the LPA.
OR
b)The applicant shall install gas protection measures as a precautionary measure without first investigating the site. The details of these measures shall be submitted to, and approved by, the LPA.

c) For a) and b) all required measures shall be installed before the development is first occupied.