Chris Walford

From: Andrius Lescinskas <Andrius.Lescinskas@glenfarrow.co.uk>
Sent: 05 June 2018 14:02
To: Chris Walford
Cc: Clair Putz; Adam Thompson; 30720davidrobinson
Subject: RE: Rookery Farm Biomass boilers
Attachments: HFM 180_74 Data Sheet.pdf; GF295 001(2) Elevations Front Scaled.pdf; GF295 002 Elevations Top and Rear.pdf; GF295 002(1) Elevations Rear Scaled.pdf; GF295 002(2) Elevations Top Scaled.pdf; GF295 001 Elevations.pdf; GF295 001(1) Elevations Side Scaled.pdf; GF-Bio Rook1.pdf; GF-Bio Rook2.pdf

Hello Chris,

Further to your email to Adam, please find the drawings attached.
Also I included the burner fan spec sheet, which states that the fan sound level is up to 93 dB(A) (1m) in free air. The fan is located at the rear of the boiler, covered with the box, which theoretically should reduce it down to around 81 dB(A). I believe Adam already sent you the emission certificates.

Please do not hesitate if you require any other information.

Kind regards,
Andrius Lescinskas | Biomass Technical Manager | 07850621088
Glen Farrow UK Ltd | 01775 722327 | glenfarrow.co.uk
Glendum Close, Pinchbeck, Spalding, LINCS, PE11 3DQ

All work is carried out and goods are supplied subject to our Terms and Conditions of Sale which can be found on our website here.

Approved / Accredited by:
Anglian Water | CHAS | ConstructionLine | GasSafe (95542) | NIC EIC | OFTEC | Safecontractor

Glen Farrow UK Ltd • Registered Office: as above • Registered in England No: 1045218 • VAT No: 119 322 488
The information in this email and any files transmitted with it is confidential and intended solely for the addressee. If you are not the intended recipient, any disclosure, copying, distribution or action taken in reliance on its contents is prohibited and may be unlawful. If you have received this email in error please notify the sender.

From: Chris Walford <ChrisW@peterhumphrey.co.uk>
Sent: 04 June 2018 12:40
To: Adam Thompson <adam.thompson@glenfarrow.co.uk>; 30720davidrobinson <david@rookeryfarmpacking.co.uk>
Cc: Clair Putz <clair@rookeryfarmpacking.co.uk>; Paul Kitchen <Paul.Kitchen@glenfarrow.co.uk>; Andrius Lescinskas <Andrius.Lescinskas@glenfarrow.co.uk>
Subject: RE: Rookery Farm Biomass boilers

Hi Adam

Many thanks for your email.

Ideally I would like the following to accompany my planning application:

- Scaled elevations for the boilers (front/side/rear) – in PDF to scale or DWG is fine.

- Plan of the boilers – again in PDF to scale or DWG is fine.
- Data in relation to noise and any emissions from the systems.

Regards,

Chris Walford BA (Hons), MArch, PG Dip ARCH, RIBA
Chartered Architect
- **Peter Humphrey Associates Ltd. -** www.peterhumphrey.co.uk
- **Ashwood Plots -** www.ashwoodplots.co.uk

Tel: 01945 466966
Email: chrisw@peterhumphrey.co.uk

From: Adam Thompson [mailto:adam.thompson@glenfarrow.co.uk]
Sent: 04 June 2018 11:55
To: 30720davidrobinson <david@rookeryfarmpacking.co.uk>; Chris Walford <ChrisW@peterhumphrey.co.uk>
Cc: Clair Putz <clair@rookeryfarmpacking.co.uk>; Paul Kitchen <Paul.Kitchen@glenfarrow.co.uk>; Andrius Lescinskas <Andrius.Lescinskas@glenfarrow.co.uk>
Subject: RE: Rookery Farm Biomass boilers

Hi David,

Many thanks for the email below and call this morning.

Yes we will indeed assist with providing any particulars on the Biomass Boilers as possible, to help with this planning permission application. Chris if you can send across any details you need, I will get this back to you ASAP. My colleague Andrius is also back in the office tomorrow who is best to advise on the more technical details of the Boilers.

Best regards,

Mr Adam Thompson | Biomass Co-ordinator| 01775 729559
Glen Farrow UK Ltd | 01775 722327 | glenfarrow.co.uk
Glendum Close, Pinchbeck, Spalding, LINCS, PE11 3DQ

All work is carried out and goods are supplied subject to our Terms and Conditions of Sale which can be found on our website here.

Approved / Accredited by:
Anglian Water | CHAS | ConstructionLine | GasSafe (95542) | NIC EIC | OFTEC | Safecontractor

Glen Farrow UK Ltd • Registered Office: as above • Registered in England No: 1045218 • VAT No: 119 322 488
The information in this email and any files transmitted with it is confidential and intended solely for the addressee. If you are not the intended recipient, any disclosure, copying, distribution or action taken in reliance on its contents is prohibited and may be unlawful. If you have received this email in error please notify the sender.

From: David Robinson [mailto:david@rookeryfarmpacking.co.uk]
Sent: 04 June 2018 11:49
To: Chris Walford <ChrisW@peterhumphrey.co.uk>
Cc: Adam Thompson <adam.thompson@glenfarrow.co.uk>; Clair Putz <clair@rookeryfarmpacking.co.uk>
Subject: Rookery Farm Biomass boilers

Hi Chris,

Good to see you this morning.

As I mentioned we are looking to install 2 x GF295 biomass boilers at Rookery Farm , but now need planning permission to qualify for the RHI payments.

The boilers are manufactured by Glen Farrow of Spalding, their guys will also be installing them.

I have made contact with Adam Thomson at Glen Farrow and he is happy to provide you with any further information/ drawings you may require. I have copied him into this email and you should be able to pickup his address from here. Glen Farrow phone number is 01775 722327, which takes you to their switchboard, after selecting option 3 you can then ask to speak to Adam.

As usual we need to crack on with this asap.

Hope this helps

David

David Robinson

Director

Rookery Farm Packing Limited

Mobile 07584 098754

www.rookeryfarmpacking.co.uk