Online Comment

Application	H06-0616-18
Location	ROOKERY FARM JOYS BANK HOLBEACH ST JOHNS PE12 8SD
Proposal	Proposed extension to existing glasshouses, additional reservoir and 2 No. biomass boilers

---

Name	Steve Branson
Address	SHDC Priory Road
Date Submitted	16-07-18
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5 dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.