

Online Comment

Application H06-0960-21
Location NORFOLK HOUSE FARM MAIN ROAD GEDNEY DROVE END PE12 9PB
Proposal Proposed glasshouse containing hydroponic growing system, glasshouse annex containing seeding & germination processes, main pack building, admin & welfare building, main plant room, external roads & hardstandings and landscaping.

Name Steve Branson
Address SHDC Priory Road

Date Submitted 29-09-21
For/Against Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A) eq at any residential boundary not within the applicant's ownership.