Online Comment

Application	H06-1074-19
Location	BROWNS FARM DAWSMERE BANK GEDNEY PE12 9NN
Proposal	Proposed plastic clad greenhouse for plant breeding and propagation with associated reservoir and fencing

---

Name	Steve Branson
Address	South Holland District Council Priory Road
Date Submitted	31-12-19
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5 dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.