

PROPOSED EXTENSION, GARAGE AND STABLE BLOCK AT
CORDON VILLA, 24, STATION ROAD, GEDNEY HILL,
SPALDING, PE12 0NP
FLOOD RISK ASSESSMENT



View of rear of property

S M Hemmings B Sc C Eng MICE MIWEM,
13 Lea Gardens,
Peterborough,
PE3 6BY
stuart.hemmings@btinternet.com

This flood risk assessment has been prepared solely to support the planning application for a proposed extension, garage and stable block at Station Road, Gedney Hill. The author has made every effort to provide an accurate assessment of the flood risk but accepts no liability should the information be found to be incorrect or incomplete, or if it is used for any other purposes other than for which it was originally commissioned.

Introduction


A planning application is due to be submitted to South Holland District Council for permission to construct an extension, garage and a stable block at Cordon Villa, 24, Station Road, Gedney Hill, Spalding.

The site is within Flood Zone 3 as shown on the Environment Agency's Flood Zone Map. These maps do not take into account existing flood defences.

The Planning Application requires a Flood Risk Assessment to be carried out as specified in the Practice Guidance to the National Planning Policy Framework Development and Flood Risk. The site is shown within the defended area of the South Holland District Council's Strategic Flood Risk Assessment (SHDC SFRA) map and is located in the South Holland Internal Drainage Board district.

Environment Agency (EA) Flood Zones

The map below is taken from the Environment Agency website and shows the flood zones in the area.



It can be seen that the existing house and the proposed site of the garage and stable block are all within flood zone 3.

Application Site

This development in Gedney Hill is equidistant from the River Welland to the west and the River Nene to the west and south. The National Grid Reference of the site is 533550 310865.

The location of the site is shown on the plan at the end of this document.

As the site is within a defended area the proposed development can be considered to be within Flood Zone 3(a) as detailed on the Environment Agency's flood zone maps without defences, as defined in Table 1 of the Technical Guidance.

Applying the flood risk vulnerability classification in Table 2 of the Guidance, a residential development is classified as "more vulnerable", and the garage and stable block as less vulnerable.

Table 3 of the Guidance is shown below:

<u>Flood Zones</u>	<u>Flood Risk Vulnerability Classification</u>				
	Essential infrastructure	Highly vulnerable	More vulnerable	Less vulnerable	Water compatible
Zone 1	✓	✓	✓	✓	✓
Zone 2	✓	Exception Test required	✓	✓	✓
Zone 3a †	Exception Test required †	X	Exception Test required	✓	✓
Zone 3b *	Exception Test required *	X	X	X	✓*

Therefore it can be seen that "Less Vulnerable" development is acceptable in flood zone 3(a) and the sequential and exception test do not need to be applied to a development of an extension to an existing dwelling.

Sequential Test

The aim of the Sequential Test, as set out in the Planning Practice Guidance, is to ensure that a sequential approach is followed to steer new development to areas with the lowest probability of flooding. The flood zones as defined in the Strategic Flood Risk Assessment for the area provide the basis for applying the Test. The aim is to steer new development to Flood Zone 1 (areas with a low probability of river or sea flooding). Where there are no reasonably available sites in Flood Zone 1, local planning authorities in their decision making should take into account the flood risk vulnerability of land uses and consider reasonably available sites in Flood Zone 2 (areas with a medium probability of river or sea flooding), applying the Exception Test if required. Only where there are no reasonably available sites in Flood Zones 1 or 2 should the suitability of sites in Flood Zone 3 (areas with a high probability of river or sea flooding) be considered, taking into account the flood risk vulnerability of land uses and applying the Exception Test if required.

As the development proposed is for an extension to the existing house and the erection of a stable block stable it is not possible to locate the stable at an alternative location.

Therefore it is considered that the sequential test is passed.

Strategic Flood Risk Assessment

The Strategic Flood Risk Assessment (SFRA) written for the South Holland District Council (SHDC) in 2010 provides details of the actual flood risk in the Council's area. This information has not been updated and reference to the maps in this document give the following information for the actual flood risk and hazard at the site for the 1% fluvial event and 0.5% tidal event.

For the present day	Depth of flooding ... zero
	Extent of flooding .. Low or medium
	Velocity zero
For year 2115	Depth of flooding ... zero
	Extent of flooding .. Low or medium
	Peak Velocity zero

The maps showing the residual flood hazard were revised in the 2016 update of the South Holland District Council Strategic Flood Risk Assessment which can be found on the website of the South East Lincolnshire Joint Planning Committee. The hazards are as follows for the 1% fluvial or 0.5% tidal event probability:

For the present day	Depth of flooding.... zero
	Extent of flooding ...low or medium
	Hazard zero
	Velocity zero
For the year 2115	Depth of flooding .. zero
	Extent of flooding ...low or medium
	Hazard zero
	Velocity zero

Figure 16 of the general maps shows that the site is not within the rapid inundation zone for the present day or in 2115.

Maximum flood level and bank levels in the River Welland

The maximum levels in the fluvial section of the River Welland 9.3 km west of the site are as follows:


	2007	2115
Peak 1 in 200 year level	4.65m OD	4.74m OD
Peak 1 in 1000 year level	4.67m OD	4.74m OD

The defence level (top of Barrier Bank) at chainage 6.8km is between 5.80m and 6.10m OD and is 7.7km east of the site.

Information on Surface Water Flooding on Environment Agency Website

The map on the next page shows areas around the site where there is a low risk of surface water flooding. The light blue areas indicate the low risk of up to 300mm of

surface water flooding, and the darker blue areas indicate that between 300mm and 900mm of surface water flooding could occur.



It can be seen the map does not predict any surface water flooding at the site of the proposed development.

Existing Flood Alleviation Measures

The site is within a defended flood plain, as defined in Appendix 1 of the Environment Agency's "Policy and Practice for the Protection of Flood Plains", which is considered to be passive until such time that a flood greater than the defences can withstand occurs. The likelihood of flooding occurring due to overtopping or failures of the defences is considered to be very low.

The site is located approximately 9.3 km from the tidal section of the River Nene, which is maintained by the Environment Agency.

The site is located approximately 9.3 km from the fluvial section of the River Welland, which is maintained by the Environment Agency.

The site is located approximately 5.1 km south of the South Holland Main Drain, which is maintained by South Holland IDB.

The site is located approximately 1.9 km north of the New South Eau which is the main watercourse that flows into the North Level Main Drain, both of which are maintained by North Level IDB.

The main watercourses in this area of Gedney Hill are maintained by South Holland IDB.

Existing Ground Levels

The level of Station Road is approximately 2.40m ODN and the ground level around the existing house is between 400mm and 600mm below the road level. The field where the stable block is proposed is approximately 200mm lower than the area around the house.

The ground floor level of the property is between 150mm and 200mm above the gravelled hardstanding south of the house.

Potential Sources of Flooding

The potential sources of flooding to the site are:-

1. Failure or overtopping of tidal defences of the River Nene.
2. Failure or overtopping of fluvial defences of the River Welland (Barrier Bank).
3. Overtopping of the South Holland Main Drain.
4. High water levels in IDB drainage channels.
5. Localised surface water flooding.

1. Failure or overtopping of tidal defences of the River Nene

The north bank of the River Nene is approximately 9.2 km south of the site of the proposed development. The hazard from a breach in the River Nene east of the development site will be considered to be the major risk to the site.


The maps available on the South East Lincolnshire Local Plan website show that there is no predicted risk of tidal or fluvial flooding in this area of Gedney Hill in a 1 in 200 year event in 2115.

The New South Eau 1.8km south of the site will intercept any flood flows emanating from the River Nene and reduce the risk of flooding to the Gedney Hill area.

Adequate mitigation against the risk of flooding from this source will be provided by raising the ground floor level of the stable by 150mm above the existing level.

2. Overtopping of the Barrier Bank.

The section of the River Welland from south of Crowland to the southern outskirts of Spalding has two washlands located on the east side of the River, called Crowland Washlands and Cowbit Washlands. These areas are designed to alleviate very high flows in the River Welland. When the water level in the River Welland reaches a level of approximately 5.00m OD large syphons are activated which discharge excess water onto the Washes. The Barrier Bank is located on the east side of the Washes to contain the water in the Washlands and is the main flood defence bank on the east side of the river.



The Washes are only flooded in extreme conditions (around 1 in 50 years) and are used the rest of the time as agricultural land. If a breach occurred in the Barrier Bank in this scenario then flood water would flow eastwards towards the proposed development.

The risk of flooding from this source, as the site is 8.9 km from the Barrier Bank, can be considered to be very low. Adequate mitigation against the risk of flooding from this source will be provided by raising the ground floor level of the stable by 100mm above the existing level.

3. Overtopping of the South Holland Main Drain

There is a risk of flooding to the site if water levels in the South Holland Main Drain were to become very high and flood onto the surrounding land. This watercourse is 5.1km north of the proposed site.

The risk of this can be considered to be low as the normal water level of the Main Drain is approximately 0.0m OD and predicted levels in a 1 in 100 year event stay within bank.

Therefore with the added precaution that ground floor level of the stable will be raised by 100mm above the existing ground level this source of flooding can be considered to be adequately mitigated.

4. High Water Levels in IDB drains

Although the whole of this area is below high tide level in the Wash and the River Nene, the retained water levels in the drainage channels ensure that the risk of flooding is extremely low. South Holland IDB maintains a system of sluices, pumping stations, and drainage channels which convey surface water into the River Nene and the Wash and control water levels throughout the South Holland IDB area.

There are possibilities of failure of outfall sluices, but these are mitigated by the high level of maintenance given to these structures by the IDB. If a failure did occur the IDB would immediately be warned of the problem by their telemetry system and take action to repair the fault or to bring in temporary pumps to reduce the risk of any flooding in the area. Similarly any failures of culverts or other blockages would be dealt with immediately.

IDB systems are designed to provide a freeboard of between 600mm and 1000mm to all land in a 1 in 10 year return period rainfall event. This normally provides a standard of service of between 1 in 50 years and 1 in 100 years against flooding. In an extreme event water levels will rise but this will be a slow process and it would be at least 24 hours before levels were high enough to begin to flood low land in the area.

South Holland IDB have a policy of monitoring standards of protection in all their catchments and will carry out improvements to pumping stations, sluices and drainage channels to ensure they continue to provide satisfactory standards of protection with higher run-offs predicted with climate change.

It is assumed that the site drains westwards into a dyke 200 metres west of the site, which flows northwards into an IDB watercourse 100 metres north of the site. This flows eastwards into the Highstock Drain, which is maintained by South Holland IDB. Highstock Drain is 250 metres east of Station Road and flows northwards and then flows into an east – west drain which flows under North Road to join Fleet Drain located approximately 350 metres west of North Road. The level of Fleet Drain is controlled by Fleet Pumping Station which pumps into the South Holland Main Drain.

The water level in the South Holland Main Drain is controlled by the sluice alongside Nene Way 1.5km south of Sutton Bridge, where the water discharges into the tidal River Nene at low tide.

It is unlikely that any failure of assets such as pumping stations, sluices or drainage channels would lead to overtopping of the watercourse because South Holland IDB have an excellent maintenance regime and monitor all assets with a modern telemetry system.

Therefore the IDB system provides an adequate control of water levels in the area to mitigate against any flooding in a 1 in 100 year event.

5. Localised Flooding due to failure of local drainage systems

Any localised flooding that could occur on the site will be mitigated by raising the floor level of the proposed stable by 100mm above the existing ground level.

Extent of known Flooding

During the preparation of this assessment, no evidence was discovered of this field or any of the adjoining land having been flooded in the past fifty years.

Probabilities and Trends of Flooding

The probability of this development flooding from Environment Agency main river is very low. In an extreme event any effect on this location would not be sudden and there would be time for people on the site to make arrangements to protect the horses and to take precautionary measures to limit the impact of any flooding that may occur.

Residual Risk – Extreme Events

The residual risk from extreme events is very low on this site. The major risk to the site is from a breach or overtopping of the tidal defences

The risk of this happening in this case is low and the hazard from any flooding is also low.

Climate Change

The predictions of flood depths for this flood risk assessment use information provided by the Environment Agency which was produced in 2006. The EA have issued new guidance on recommended contingency allowances for predicted sea level rises, fluvial flows and rainfall intensities which from 19th February 2016 needs to be considered in the FRA. The effects of these new recommendations are considered in

Appendix A of this report (pages 13 to 16). It is concluded that no extra mitigation measures are necessary to comply with the new guidance on climate change.

South East Lincs Advice Matrix


Advice can be found on the recommended mitigation required by referring to a spreadsheet on the South East Lincolnshire website.

As the development is a residential development in flood zone 3 and there is no flood hazard, reference should be made to Category H4 which states “No Comment”

Summary of Risk of Flooding to the Site

The main risk of flooding to the site is if a breach were to occur in the west bank of the tidal River Nene. The risk of this happening along this section of bank can be considered to be low. The bank has a wide top and bank slopes are not steep.

The relevant part of the map showing the predicted peak depths in this area if a breach occurred in the west bank of the River Nene in 2115 in a 0.5% tidal event probability or a breach occurred in the bank of the River Welland in a 1.0% fluvial event is shown on the next page.



It can be seen that there is no predicted flooding in the whole area of Gedney Hill and Holbeach Drove in a 1 in 100 year fluvial event or a 1 in 200 year tidal event in 2115.

There are no maps available from the Environment Agency showing predicted flood depths in this area of South Holland DC in a 1 in 1000 year event in 2115. However it can be assumed that the predicted flooding west of Gedney Hill shown on the map above may extend further east but will not extend to lead to any flooding in the Gedney Hill area in a 1 in 1000 year event in 2115.

The risk of flooding from high water levels in the IDB system is extremely low.

Recommendations

It is recommended that the ground floor of the proposed extension should be constructed with the finished ground floor level at the same level as the existing dwelling.

It is recommended that the new extension should be designed and constructed with flood resilient measures incorporated. These measures will include;

- All electrical services should be placed at first floor level and cables dropped down to the sockets, which should be a minimum of 600mm above the floor level.
- Skirting boards and plaster finishes should be able to withstand flood damage if 150mm of water entered the building and remained for a few days.
- Suitable tiles should be used as flooring in the new extension.

It is recommended that the floor level of the proposed stable should be a minimum of 100mm above the ground level in the field.

The owner of the property should register with the Environment Agency's Floodline Warnings Direct Service.

The future occupier of this property should register with the Environment Agency's Floodline Warnings Direct Service to receive automated early warnings of potential flooding.

Rainwater from the roofs of the proposed house should if possible be discharged into soakaways and these should be designed to BRE Digest 365 and approved under Building regulations.

S M HEMMINGS B Sc C Eng MICE MIWEM


stuart.hemmings@btinternet.com

29th April 2024


LOCATION PLAN



PLAN OF IDB DRAINS



BLOCK PLAN OF PROPOSED DEVELOPMENT



APPENDIX A CLIMATE CHANGE

The Environment Agency has issued revised guidance on climate change and have now stated that the new predictions should be considered and incorporated into all flood risk assessments produced after 19th February 2016.

Listed below are the climate change allowances in three documents:

- South Holland SFRA
- EA guidance (2013)
- Revised EA guidance

The recommendations in each document are shown below.

2010 South Holland DC SFRA

The SHDC SFRA states that the the following allowances have been made for climate change:

4.4 Climate Change

Scenarios for the years 2055 and 2115 include for climate change contingency allowances to the amount suggested by PPS25¹. These allowances are expressed in Table 2. Percentage increases are relative to the present-day.

Table 2 – Adopted Climate change contingency allowances

Parameter	Year 2055	Year 2115
Sea level rise (m)	+ 0.33	+ 1.14
Extreme wave height	+ 10%	+ 10%
Peak river flow and volume	+ 20%	+ 20%
Peak rainfall intensity	+ 20%	+30%

Where flows arise from pumping rather than natural run-off, notably in the Vernatt's Drain and for the Fenland subcatchments of the South Forty Foot Drain, peak flow rates for future eras have been taken as equal to current rates since this SFRA assumes all flood risk management measures will remain in their current state.

2013 Guidance to Planners

Guidance to planners was issued by EA in September 2013

Table 1: Recommended contingency allowances for net sea level rises (Net sea level rise (mm per year) relative to 1990)

	1990 to 2025	2025 to 2055	2055 to 2085	2085 to 2115
East of England, east midlands, London, south-east England (south of Flamborough Head)	4.0	8.5	12.0	15.0
South-west England	3.5	8.0	11.5	14.5
North-west England, north-east England (north of Flamborough Head)	2.5	7.0	10.0	13.0

Table 2: Recommended national precautionary sensitivity ranges for peak rainfall intensity, peak river flow, offshore wind speed and wave height

Parameter	1990 to 2025	2025 to 2055	2055 to 2085	2085 to 2115
Peak rainfall intensity	+5%	+10%	+20%	+30%
Peak river flow	+10%	+20%		
Offshore wind speed	+5%		+10%	
Extreme wave height	+5%		+10%	

Revised 2016 EA Guidance

Table 1 peak river flow allowances by river basin district (use 1961 to 1990 baseline)

River basin district	Allowance category	Total potential change anticipated for '2020s' (2015 to 39)	Total potential change anticipated for '2050s' (2040 to 2069)	Total potential change anticipated for '2080s' (2070 to 2115)
Anglian	Upper end	25%	35%	65%
	Higher central	15%	20%	35%
	Central	10%	15%	25%

For more vulnerable development in flood zone 3 the higher central and the upper end should be used to assess the range of allowances.

Table 2 peak rainfall intensity allowance in small and urban catchments (use 1961 to 1990 baseline)

Applies across all of England	Total potential change anticipated for 2010 to 2039	Total potential change anticipated for 2040 to 2059	Total potential change anticipated for 2060 to 2115
Upper end	10%	20%	40%
Central	5%	10%	20%

Table 3 sea level allowance for each epoch in millimetres (mm) per year with cumulative sea level rise for each epoch in brackets (use 1990 baseline)

Area of England	1990 to 2025	2026 to 2050	2051 to 2080	2081 to 2115	Cumulative rise 1990 to 2115 / metres (m)
East, east midlands, London, south east	4 (140 mm)	8.5 (212.5 mm)	12 (360 mm)	15 (525 mm)	1.24 m

Table 4 offshore wind speed and extreme wave height allowance (use 1990 baseline)

Applies around all the English coast	1990 to 2050	2051 to 2115
Offshore wind speed allowance	+5%	+10%
Offshore wind speed sensitivity test	+10%	+10%
Extreme wave height allowance	+5%	+10%
Extreme wave height sensitivity test	+10%	+10%

Effects on Predictions of Flood Risk in FRA

The FRA has identified the main source of flooding where the new climate change recommendations could affect the predictions of flood levels in 2115 at the development site is flooding from the tidal River Nene

The contingency allowance in metres for the years 2055 and 2115 using 1990 as a baseline in the SFRA compared with the guidelines is as follows

Year	SFRA	2013 guidance	Revised 2016 guidance
2055	0.33	0.395	0.412
2115	1.14	1.205	1.24

Therefore it can be seen that the revised guidance increases the maximum allowance for sea rise in 2115 by 100mm. This will not have the effect of increasing the predicted flood level at the site in a 1 in 200 year breach event in 2115 by the maximum of 100mm, but it will probably be only between 10mm and 50mm. It is unlikely that this increase will significantly change the maps of flood risk at present issued by the Environment Agency.

Flooding from IDB drainage system

As the development is in flood zone 2 and is classed as more vulnerable, the advice from the Environment Agency is that the higher central climate change allowance, which is 35%, should be considered. After considering the effects of this increase the upper end allowance, which is 65%, should be considered to assess the effect of this.

IDB's have been using an allowance of 20% for climate change over the past few years in their assessments and modelling of their systems. Generally IDB's are happy that their systems provide a 1 in 100 year standard to most urban areas at the present time.

South Holland IDB, and all IDB's, are aware that climate change will affect the operations of pumping stations, sluices and drainage channels. Pumping stations and sluices only have a 30 year life and will need to be refurbished or rebuilt within this timespan. It is assumed that South Holland IDB will continue to review the modelling they have already carried out and when the Board consider these refurbishments adequate arrangements will be made to incorporate the latest climate change projections in order that the Board continues to provide the same standard of service as the present day.

Therefore it is considered that the mitigation proposed for the development, with the recommendation that the floor levels of the proposed extension should be the same as existing and the stable should be raised by 100mm is satisfactory.