Online Comment

Application	H07-1067-20
Location	72 WEST DROVE NORTH GEDNEY HILL SPALDING PE12 0NT
Proposal	Extension to dwelling to provide self-contained annexe

---

Name	Sue Armour
Address	Environmental Protection Officer SHDC PE11 2XE
Date Submitted	07-01-21
For/Against	Comments

I request that the following note be placed on any permission granted:

Our records indicate that the above site is in the vicinity of filled land from which there is the potential for soil gas migration. Therefore as a precautionary measure it is recommended that either the above development includes gas protection measures and that all service entry points are sealed, or a site investigation may be undertaken to provide site specific assessment which would need to be acted on accordingly. The developer is referred to the BRE report 414, current British Standards for guidance and other similar guidance.