

Gedney, Oliver

From: Grant, David
Sent: 10 November 2021 14:27
To: _planningadvice
Subject: FW: H08-0227-21 (Additional Information) - Erection of two industrial buildings - SMC Belchmire Lane, Gosberton, PE11 4HG - HCS Cladding

Please add this email to the file under 6SUP – Proposed impermeable area.

Many thanks.

David Grant | Senior Planning Officer | **South Holland District Council**

Direct Dial: 01775 764472

www.sholland.gov.uk

Please note that any informal officer opinion expressed by this email is without prejudice and is not binding on the Council during the consideration of any formal application.



served by One Team

From: Timothy Leach <tim.leach@tl-design.co.uk>
Sent: 10 November 2021 13:29
To: Jane Picking <jane@wellandidb.org.uk>; Grant, David <dgrant@sholland.gov.uk>
Cc: Craig Shinkin <Craig@wellandidb.org.uk>
Subject: RE: H08-0227-21 (Additional Information) - Erection of two industrial buildings - SMC Belchmire Lane, Gosberton, PE11 4HG - HCS Cladding

This message originated from outside your organization

Hi

I can confirm that the proposed impermeable area draining to the Risegate Eau at 5l/s is 3960m²

The contractor is proposing a reinforced concrete outlet as shown below and we will detail concrete revetment blocks below this, down to mean water level, to prevent bank scour.

Can you please confirm the associated contributory charges and that the principles for the outfall design are acceptable?

Many thanks,



Tim Leach
(07843) 205761
Tim.leach@tl-design.co.uk

From: Jane Picking <jane@wellandidb.org.uk>
Sent: 10 June 2021 08:41
To: David Grant (dgrant@sholland.gov.uk) <dgrant@sholland.gov.uk>
Cc: planningadvice@sholland.gov.uk; Timothy Leach <tim.leach@tl-design.co.uk>; Jon Sharpe <Jon.Sharpe@lincolnshire.gov.uk>; Craig Shinkin <Craig@wellandidb.org.uk>
Subject: H08-0227-21 (Additional Information) - Erection of two industrial buildings - SMC Belchmire Lane, Gosberton, PE11 4HG - HCS Cladding

For and on behalf of Craig Shinkin, Planning & Enforcement Officer

Dear Mr Grant

Please find attached copy letter in respect of the above.

Many thanks

JANE PICKING

Secretary



Deeping House

Welland Terrace

Spalding

PE11 2TD

www.wellandidb.org.uk

Tel: 01775 725861

Fax: 01775 767689

The e-mail you have received and any files transmitted with it are intended solely for the use of any individual or entity to whom they are addressed. However, the information may be subject to public disclosure under the Freedom of Information Act 2000. Unless the Information is legally exempt from disclosure, the confidentiality of this e-mail and your reply cannot be guaranteed.

All e-mail sent to or from this address will be processed by Welland and Deepings Internal Drainage Board E-mail system and as such may be subject to recording and/or monitoring in accordance with relevant legislation.

If you have received this e-mail in error please notify the sender immediately by using the e-mail address or telephone +44 (0) 1775 725861