

Online Comment

Application H08-0695-16
Location Bank House Farm 5 Cooks Road Gosberton PE11 4PE
Proposal Proposed side extension for use as cold storage for agricultural use

Name Steve Branson
Address Environmental Health Technician Safety and Environment

Date Submitted 17-08-16
For/Against Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background level by more than 5 dB(A) when measured as a 15 minute LAeq at any residential boundary not within the applicant's ownership.