Online Comment

Application	H08-0760-24
Location	Riseholme Farm Windmill Lane Gosberton Risegate PE11 4ES
Proposal	Details of site section/levels, boundary treatment & external materials, landscaping, waste collection points or private refuse/recycling collection, remediation method statement, construction management plan, acoustic fencing & acoustic window details, design & position of external meter boxes etc and scheme detailing external lighting (Conditions 4, 5, 6, 7, 8, 10, 11, 14 and 15 of H08-0282-24)

Name	Sue Armour - Lighting comments
Address	Team Leader Environmental Protection SHDC
Date Submitted	06-11-24
For/Against	Comments

I have reviewed the proposal for lighting at the location and have had regard to the Institute of Lighting Professionals Guidance Note 9/19 'Domestic exterior lighting: getting it right!' Although the properties are close together, the use of low lumen bulbs (7W est c.500 lumens) in the up/ down wall lights would conform with the guidance note and would be unlikely to give rise to nuisance given the way the lights are angled.
Regarding the bollards, whilst the low height and the solid top should prevent upward light pollution, they will be quite bright at 2000 lumens, however given the positioning they would be unlikely to give rise to nuisance.
However I do have concerns regarding the bulkhead lighting, in particular on plots 4 and 5, and to a lesser extent on plot 3, where the lights are facing directly at other properties. The bulkhead lights are shown as 1250 lumen, which is above the 600-900 lumens recommended by the ILP. I recommend a reduction in this case.