HIGHWAY AND LEAD LOCAL FLOOD AUTHORITY RESPONSE TO CONSULTATION ON THE FOLLOWING DEVELOPMENT PROPOSAL

District: South Holland District Council
Application number: H08-0779-26
Application Type: full planning application
Proposal: Erection of detached dwelling
Location: Adjacent to 3-4 Bowgate, Gosberton, Spalding, PE11 4ND
Response Date: 26 August 2026
Response by: Kelly Austwick

This report includes the Substantive response of the Local Highway and Lead Local Flood Authority to a planning consultation received under the Development Management Order and includes details of any planning conditions or informatives that should be attached in the event that permission is granted and any obligations to be secured by way of a S106 agreement.

General Information and Advice

Please note that although the Definitive Map and Statement proves the existence of any recorded rights of way, there may be further or higher rights that are not shown on this document that the County Council is not currently aware of. This would be especially relevant where the public has had informal access to the site or where there are references to routes across this in maps or other historic documents. As the County Council has received no application to recognise further rights of way affecting the site, no more informed guidance can be offered at this stage.

Highway and Lead Local Flood Authority Report

Substantive Response provided in accordance with article 22(5) of The Town and Country Planning (Development Management Procedure) (England) Order 2015:

Recommendation for No objection subject to:

No Objections

Having given due regard to the appropriate local and national planning policy guidance (in particular the National Planning Policy Framework), Lincolnshire County Council (as Highway Authority and Lead Local Flood Authority) has concluded that the proposed development would not be expected to have an unacceptable impact upon highway safety or a severe residual cumulative impact upon the local highway network or increase surface water flood risk and therefore does not wish to object to this planning application.

As Lead Local Flood Authority, Lincolnshire County Council is required to provide a statutory planning consultation response with regard to drainage and surface water flood risk on all Major applications. This application is classified as a Minor Application and it is therefore the duty of the Local Planning Authority to consider the surface water flood risk and drainage proposals for this planning application.

Comments:

The visibility at the access complies with Manual for Streets (MfS). Road has a speed limit of 30 mph and is an A road, but due to factors including the frequency of junctions, alignment of the road and driver behaviour; visibility in accordance with MfS is deemed appropriate rather than visibility set out in DMRB which are Department for Transport standards for Trunk Roads.

Informatives

Highway Informative 02

In accordance with Section 59 of the Highways Act 1980, please be considerate of causing damage to the existing highway during construction and implement mitigation measures as necessary. Should extraordinary expenses be incurred by the Highway Authority in maintaining the highway by reason of damage caused by construction traffic, the Highway Authority may seek to recover these expenses from the developer.

Highway Informative 03

The permitted development requires the formation of a new/amended vehicular access. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. Any traffic management required to undertake works within the highway will be subject to agreement. The access must be constructed in accordance with a current specification issued by the Highway Authority. Any requirement to relocate existing apparatus, underground services, or street furniture because of the installation of an access will be the responsibility, and cost, of the applicant and must be agreed prior to a vehicle access application. The application form, costs and guidance documentation can be found

on the Highway Authority's website, accessible via the following link: https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb.

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections, Section 50 licences and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit the Highway Authority's website via the following link: Traffic Management - https://www.lincolnshire.gov.uk/traffic-management

Officer's Name: Kelly Austwick
Officer's Title: Senior Development Management Officer
Date: 26 August 2026