

## Online Comment

**Application** H08-0954-25  
**Location** Riseholme Farm Gosberton Risegate PE11 4ET  
**Proposal** Proposed Detached 4 Bed Dwelling

---

**Name** Diane Gordon  
**Address** SHDC Environmental Protection

**Date Submitted** 12-02-26  
**For/Against** Comments

the noise and vibration report 03783-590101 produced by Blue tree acoustics has been reviewed.

the conclusions of these advise that the proposed 2.5m high full acoustic fencing to the rear boundary is appropriate to achieve sufficient sound reduction . this would ensure that night time levels are attenuated to an appropriate level to meet an acceptable standard of amenity of the occupants. we would therefore support the construction of an appropriate barrier fence.

+