SALLY WALTHAM
BA (Hons) F.C.I.H.
Director of Housing & Planning Services

Housing and Planning
Services Department,
Council Offices,
Priory Road,
Spalding,
Lincolnshire. PE11 2XE

Telephone: (01775) 761161
Fax: (01775) 710772

FILE COPY

SOUTH HOLLAND DISTRICT COUNCIL
HOUSING & PLANNING SERVICES DEPARTMENT

Town and Country Planning Act 1990

Approval required by Condition of Permission

Reference: H08/1175/00 Received: 25-SEP-00 Type: CONDITION COMPLIANCE

Name: Mr D Howitt
Laburnum Cottage
Wood Lane
Quadring Eaudyke
Spalding, Lincs.

Agent: Cooper Architectural Design
Unit 4 Wrights Mews
12A Park Road
Holbeach
Spalding, Lincs.

Description: Details of acoustic fence & vents (Condition 4 of H08/0667/99)
Location : Quadring Road Gosberton
Spalding Lincs

South Holland District Council hereby give notice that CONSENT HAS BEEN GRANTED for the details submitted for the purpose of conditions attached to the planning permission, subject to any conditions below:

The determined plans are:-
1:10 scale detail and acoustic grill detail received on 25 Sep 00.

The applicant is advised that the fence should have a surface mass of at least 12 kg/m2 without holes or gaps.

Director of Housing and Planning Services
25 OCT 2000

H08/1175/00

This decision refers only to that required for the purposes of the Town and Country Planning Acts and not for Building Regulations or any other legislation. See enclosed notes relating to rights of appeal.

Town and Country Planning Act etc

DRAFT PERMISSION

Reference H08/1175/00 Received: 25-SEP-00 Type: CONDITION COMPLIANCE

Name: Mr D Howitt
Laburnum Cottage
Wood Lane
Quadring Eaudyke
Spalding, Lincs.

Agent: Cooper Architectural Design
Unit 4 Wrights Mews
12A Park Road
Holbeach
Spalding, Lincs.

Description: Details of acoustic fence & vents (Condition 4 of H08/0667/99)

Location : Quadring Road Gosberton
Spalding Lincs

South Holland District Council hereby give notice that permission has been granted (or equiv) on the following condition(s):

The determined plans are:-
1:10 scale detail and acoustic grill detail received on 25 Sep 00.

The applicant is advised that the fence should have a surface mass of at least 12 kg/m2 without holes or gaps.

Director of Housing and Planning Services
24 OCT 2000

H08/1175/00