Online Comment

Application	H09-0493-17
Location	Land: Church Street Holbeach PE12 7LL
Proposal	Contamination Report (Condition 5 of H09-0770-16)

Name	J Reith
Address	Environmental Health Technician Safety and Environment

Date Submitted	27-06-17
For/Against	Comments

The post-demolition Investigation Report by GeoDyne dated 9 May 2017 satisfies part 2 of the contaminated land condition. However as levels of contamination and asbestos fibres have been found on site I require a remediation method statement and validation report to ensure that the final development is safe for the end user. Therefore the contaminated land condition cannot be discharged until parts 3 and 4 have been submitted.