Online Comment

Application	H09-0503-23
Location	Fleet Street Holbeach Spalding PE12 7AG
Proposal	Details of surface water drainage scheme and contamination of land or pollution of controlled waters. (Conditions 7 and 10 of H09-1057-22)

Name	Sue Armour
Address	Team Leader Environmental Protection SHDC
Date Submitted	10-01-24
For/Against	Comments

I have reviewed the CRADDYS report 'Aldi Fleet Street, Holbeach Gas Risk and Protection Measures' DATE: 13/12/23 CRADDYS DOCUMENT REFERENCE: 60108w0005 and amin general agreement with the proposals. An exact membrane is not specified however it will be installed by a suitable contractor and independently validated, and I therefore recommend discharge of condition 10 of H09-1057-22, with condition 11 remaining outstanding.