Online Comment

Application	H09-0511-18
Location	Land at New River Gate Holbeach St John Spalding PE12 0RY
Proposal	Formation of a nursery involving an improved access, drive-way, vehicle turning area, the erection of glasshouses/shed and the formation of a reservoir

---

Name	Steve Branson
Address	SHDC Priory Road
Date Submitted	25-06-18
For/Against	Comments

No objection but would wish to attach the following condition:

Noise from fixed plant and machinery shall not exceed the background noise level by more than 5dB(A) when measured as a 15 minute L(A)eq at any residential boundary not within the applicant's ownership.