

[illegible]

Pipelines have been designed based on Simplified Tables of External Loads on Buried Pipelines. Pipes under Main Roads with the depth of cover related to finished construction level of road. The contractor shall ensure that overload of the pipes does not occur during construction. The following precautions shall be adopted.

- ## CDM REGULATIONS 2015

- ## DRAINAGE PIPEWORK AND BEDDING DETAILS

1. All foul water sewers shall be Extra Strength Clayware to BS EN 295
2. All 150-300mm surface water sewers shall be Extra Strength Clayware to BS EN 295. All surface water sewers of 375mm or greater shall be Concrete Class 120 to BS 5911-1:2002.
3. All pipe bedding shall be Class S, (FM 2.2), unless otherwise stated.

B	Amended to suit revised planning layout	17.08.20	JMW	TJW
A	Amended as AWS comments	30.06.20	JMW	TJW
Rev	Description	Date	Drawn	Checked

Drawing Approval Status:-

N/A Section 104 N/A Section 38 N/A Section 278

Wormald Burrows
Civil Engineering Consultants

12a - 18a Hitchin Street, Biggleswade, SG18 8AX
Tel: (01767) 317244

Web: www.wormburp.com
Email: engineer@wormburp.com

Project:

Damgate, Holbeach

Drawing Description

Longitudinal Section - Sheet 2 of 5

Client:

Drawing Number:
E3991/531/B

Client Reference

Scale: V - 1:500
H - 1:100

Designed By:
TJW
Date:
04.10.19

Drawn By:
JMW
Date:
15.10.19

Checked By:
TJW
Date:
20.11.19



©This drawing is Copyright, Wormald Burrows Partnership Limited 2018

Certified by Afnor UK